



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION

NOTICE OF ACCEPTANCE (NOA)

MIAMI-DADE COUNTY
PRODUCT CONTROL SECTION
11805 SW 26 Street, Room 208
T (786) 315-2590 F (786) 315-2599
www.miamidade.gov/economy

PGT Industries
1070 Technology Drive
North Venice, FL 34275

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER - Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami-Dade County) and/or the AHJ (in areas other than Miami-Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.-

DESCRIPTION: Series "CA-740F Fixed Casement" Aluminum Fixed Window - L.M.I.

APPROVAL DOCUMENT: Drawing No. MD-CA740F-LM, titled "Fixed Casement Window Details - LM", sheets 1 through 11 of 11, dated 08/08/12, with revision A dated 05/15/15, prepared by manufacturer, signed and sealed by Anthony Lynn Miller, P.E., bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state, model/series, and following statement: "Miami-Dade County Product Control Approved", unless otherwise noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA# 12-1218.11 and consists of this page 1 and evidence pages E-1 and E-2, as well as approval document mentioned above.

The submitted documentation was reviewed by Manuel Perez, P.E.



MP
7/15/15

NOA No. 15-0519.15
Expiration Date: April 11, 2018
Approval Date: July 16 2015
Page 1

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. Manufacturer's die drawings and sections.
(Submitted under previous NOA No. 12-1218.11)
2. Drawing No. **MD-CA740F-LM**, titled "Fixed Casement Window Details – LM", sheets 1 through 11 of 11, dated 08/08/12, with revision A dated 05/15/15, signed and sealed by Anthony Lynn Miller, P.E.

B. TESTS

1. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94
2) Uniform Static Air Pressure Test, Loading per FBC, TAS 202-94
3) Water Resistance Test, per FBC, TAS 202-94
4) Large Missile Impact Test per FBC, TAS 201-94
5) Cyclic Wind Pressure Loading per FBC, TAS 203-94
6) Forced Entry Test, per FBC 2411.3.2.1, and TAS 202-94
along with marked-up drawings and installation diagram of a series CA740F aluminum fixed casement window, prepared by Fenestration Testing Laboratory, Inc. Test Report No. **FTL-7063**, dated 09/17/12, signed and sealed by Marlin D. Brinson, P.E.
(Submitted under previous NOA No. 12-1218.11)

C. CALCULATIONS


1. Anchor verification calculations and structural analysis, complying with **FBC-5th Edition (2014)**, dated 05/16/15, prepared by manufacturer, signed and sealed by Anthony Lynn Miller, P.E.
2. Glazing complies with **ASTM E1300-04**

D. QUALITY ASSURANCE

1. Miami-Dade Department of Regulatory and Economic Resources (RER).

E. MATERIAL CERTIFICATIONS

1. Notice of Acceptance No. **14-0916.10** issued to **Kuraray America, Inc.** for their "**Kuraray Butacite® PVB Glass Interlayer**" dated 04/25/15, expiring on 12/11/16.
2. Notice of Acceptance No. **14-0916.11** issued to **Kuraray America, Inc.** for their "**Kuraray SentryGlas® (Clear and White) Glass Interlayers**" dated 06/25/15, expiring on 07/04/18.


Manuel Perez, P.E.
Product Control Examiner
NOA No. 15-0519.15
Expiration Date: April 11, 2018
Approval Date: July 16 2015

PGT Industries

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

F. STATEMENTS

1. Statement letter of conformance, complying with **FBC-5th Edition (2014)**, dated May 16, 2015, issued by manufacturer, signed and sealed by Anthony Lynn Miller, P.E.
2. Statement letter of no financial interest, dated May 16, 2015, issued by manufacturer, signed and sealed by Anthony Lynn Miller, P.E.

G. OTHERS

1. Notice of Acceptance No. **12-1218.11**, issued to PGT Industries for their Series "CA-740F Fixed Casement" Aluminum Fixed Window - L.M.I." approved on 04/11/13 and expiring on 04/11/18.


Manuel Perez, P.E.

Product Control Examiner

NOA No. 15-0519.15

Expiration Date: April 11, 2018


Approval Date: July 16 2015

GENERAL NOTES: SERIES 740
IMPACT-RESISTANT FIXED CASEMENT WINDOW

- 1) THIS PRODUCT HAS BEEN DESIGNED & TESTED TO COMPLY WITH THE REQUIREMENTS OF THE FLORIDA BUILDING CODE, INCLUDING THE HIGH VELOCITY HURRICANE ZONE (HVHZ).
- 2) SHUTTERS ARE NOT REQUIRED WHEN USED IN WIND-BORNE DEBRIS REGIONS. FOR INSULATED GLASS INSTALLATIONS ABOVE 30' IN THE HVHZ, THE OUTBOARD LITE (CAP) MUST TEMPERED.
- 3) FOR MASONRY APPLICATIONS IN MIAMI-DADE COUNTY, USE ONLY MIAMI-DADE COUNTY APPROVED MASONRY ANCHORS. MATERIALS USED FOR ANCHOR EVALUATIONS WERE SOUTHERN PINE, ASTM C90 CONCRETE MASONRY UNITS AND CONCRETE WITH MIN. KSI PER ANCHOR TYPE, SEE TABLE 3, SHEET 4.
- 4) ALL WOOD BUCKS LESS THAN 1-1/2" THICK ARE TO BE CONSIDERED 1X INSTALLATIONS. 1X WOOD BUCKS ARE OPTIONAL IF UNIT IS INSTALLED DIRECTLY TO SUBSTRATE. WOOD BUCKS DEPICTED AS 2X ARE 1-1/2" THICK OR GREATER. 1X AND 2X BUCKS (WHEN USED) SHALL BE DESIGNED TO PROPERLY TRANSFER LOADS TO THE STRUCTURE. WOOD BUCK DESIGN AND INSTALLATION IS THE RESPONSIBILITY OF THE ENGINEER OR ARCHITECT OF RECORD.
- 5) ANCHOR EMBEDMENT TO BASE MATERIAL SHALL BE BEYOND WALL DRESSING OR STUCCO. USE ANCHORS OF SUFFICIENT EMBEDMENT AS SPECIFIED ON TABLE 3, SHEET 4. NARROW JOINT SEALANT IS USED ON ALL FOUR CORNERS OF THE FRAME. INSTALLATION ANCHORS SHOULD BE SEALED. OVERALL SEALING/FLASHING STRATEGY FOR WATER RESISTANCE OF INSTALLATION SHALL BE DONE BY OTHERS AND IS BEYOND THE SCOPE OF THESE INSTRUCTIONS.
- 6) SHIMS ARE REQUIRED AT EACH ANCHOR LOCATION WHERE THE PRODUCT IS NOT FLUSH TO THE SUBSTRATE. USE SHIMS CAPABLE OF TRANSFERRING APPLIED LOADS. WOOD BUCKS, BY OTHERS, MUST BE SUFFICIENTLY ANCHORED TO RESIST LOADS IMPOSED ON THEM BY THE WINDOW.
- 7) DESIGN PRESSURES:
A. NEGATIVE DESIGN LOADS BASED ON STRUCTURAL TEST PRESSURE, FRAME ANALYSIS AND GLASS PER ASTM E1300.
B. POSITIVE DESIGN LOADS BASED ON WATER TEST PRESSURE, STRUCTURAL TEST PRESSURE, FRAME ANALYSIS AND GLASS PER ASTM E1300.
- 8) THE ANCHORAGE METHODS SHOWN HAVE BEEN DESIGNED TO RESIST THE WINDLOADS CORRESPONDING TO THE REQUIRED DESIGN PRESSURE. THE 33-1/3% STRESS INCREASE HAS NOT BEEN USED IN THE DESIGN OF THIS PRODUCT. THE 1.6 LOAD DURATION FACTOR WAS USED FOR THE EVALUATION OF ANCHORS INTO WOOD. ANCHORS THAT COME INTO CONTACT WITH OTHER DISSIMILAR MATERIALS SHALL MEET THE REQUIREMENTS OF THE FLORIDA BUILDING CODE FOR CORROSION RESISTANCE.

- 9) REFERENCES: TEST REPORTS FTL-7063, 3579, 3580, 3724; ELCO ULTRACON NOA; ELCO CRETEFLEX NOA; ANSI/AF&PA NDS FOR WOOD CONSTRUCTION AND ADM ALUMINUM DESIGN MANUAL.

DESIGN PRESSURE RATING	IMPACT RATING
VARIABLE, SEE SHEETS 6-10	RATED FOR LARGE & SMALL MISSILE IMPACT RESISTANCE





TYP. ELEVATION OF FIXED CASEMENT WINDOW

TABLE 1:

Glass Types			Sheet #
1	5/16" Lami (1/8 An - .090" PVB - 1/8 An)		6
2	7/16" Lami (3/16 An - .090" SG - 3/16 An)		8
3	7/16" Lami (3/16 HS - .090" SG - 3/16 HS)		9
4	7/8" Lami. IG (1/8" An - 7/16" Air - 1/8" An - .090" PVB - 1/8" An)		10
5	7/8" Lami. IG (1/8" T - 7/16" Air - 1/8" An - .090" PVB - 1/8" An)		7
6	7/8" Lami. IG (3/16" An - 1/4" Air - 3/16" An - .090" SG - 3/16" An)		8
7	7/8" Lami. IG (3/16" An - 1/4" Air - 3/16" HS - .090" SG - 3/16" HS)		9
8	7/8" Lami. IG (3/16" T - 1/4" Air - 3/16" An - .090" SG - 3/16" An)		8
9	7/8" Lami. IG (3/16" T - 1/4" Air - 3/16" HS - .090" SG - 3/16" HS)		9


"PVB"= BUTACITE®PVB INTERLAYER BY KURARAY AMERICA, INC.
"SG"= SENTRYGLAS®INTERLAYER BY KURARAY AMERICA, INC.

GENERAL NOTES.....	1
ELEVATION.....	1
GLAZING DETAILS.....	1
INSTALLATION.....	2
ASSEMBLY TUBE DETAILS.....	3
ANCHOR SPECIFICATIONS.....	4
ANCHOR QUANTITIES.....	4-5
DESIGN PRESSURES.....	6-10
ASSEMBLY DETAILS/BOM.....	11



1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
P.O. BOX 1529
NOKOMIS, FL 34274

CERT. OF AUTH. #29296



GLASS TYPES 8 & 9

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 15-0519.15
Expiration Date April 11, 2018
By *Manuel Cruz*
Miami Dade Product Control

Revised By:	Date:	Revision B:
LM	5/15/15	
Description:	GENERAL NOTES & ELEVATION	
Title:	FIXED CASEMENT WINDOW DETAILS - LM	
Series/Model:	CA-740	Scale: NTS
Sheet:	1 OF 11	Drawing No. MD-CA740F-LM
Rev:	A	Date: 08/08/12

INSTALLATION OPTION 1 INSTALLATION ANCHORS INTO 2X WOOD.

EDGE
DISTANCE

EDGE DISTANCE

EMBEDMENT

AS REQUIRED
PER TABLE 3,
SHEET 4

35-37

WINDOW
HEIGHT

VISIBLE
LIGHT
HEIGHT
(DLO)

EXTERIOR

BUCK
HEIGHT

INSTALLATION OPTION 2 INSTALLATION ANCHORS DIRECTLY INTO MASONRY.

TYP. ANCHOR
TYPE,
EMBEDMENT AND
EDGE DISTANCE
PER SUBSTRATE,
SEE TABLE 3,
SHEET 4.

CONCRETE/CMU
PER ANCHOR
REQUIREMENT

1/4" MAX
SHIM

EDGE
DISTANCE

EMBEDMENT

OPTIONAL ADDON
FLANGE @ HEAD,
SILL & JAMBS

NOTES:

1) USE ONLY SUBSTRATE-APPROPRIATE ANCHORS LISTED ON TABLE 3, SHEET 4. FOLLOW EMBEDMENT AND EDGE DISTANCE LIMITS. ANY INSTALLATION OPTION SHOWN MAY BE USED ON ANY SIDE OF THE WINDOW.

2) ALL WOOD BUCKS LESS THAN 1-1/2" THICK ARE TO BE CONSIDERED 1X INSTALLATIONS. 1X WOOD BUCKS ARE OPTIONAL. UNIT MAY BE INSTALLED DIRECTLY TO SUBSTRATE. WOOD BUCKS DEPICTED AS 2X ARE 1-1/2" THICK OR GREATER. 1X AND 2X BUCKS (WHEN USED) SHALL BE DESIGNED TO PROPERLY TRANSFER LOADS TO THE STRUCTURE. WOOD BUCK DESIGN AND INSTALLATION IS THE RESPONSIBILITY OF THE ENGINEER OR ARCHITECT OF RECORD. MAXIMUM SHIM THICKNESS TO BE 1/4".

1X WOOD
BUCKSTRIP,
SEE NOTE 2,
THIS SHEET.

1/4" MAX SHIM

EMBEDMENT

INSTALLATION OPTION 3 INSTALLATION ANCHORS THROUGH 1X BUCKSTRIP INTO MASONRY.

VERTICAL SECTION B-B

INSTALLATION OPTION 4 INSTALLATION ANCHORS DIRECTLY INTO METAL.

#12 STEEL
SELF-DRILLING
SMS, SEE TABLE 3,
SHEET 4.

DADE APPROVED
MULLION, ALUMINUM,
STEEL FRAMING OR
STEEL STUD.

EXTERIOR

HORIZONTAL SECTION A-A

BUCK WIDTH

AS REQUIRED
PER TABLE 3,
SHEET 4

2


35-37

VISIBLE LIGHT WIDTH (DLO)

1

WINDOW WIDTH

SEE DETAIL
A1, BELOW



10" MAX.

10" MAX.

SEE DETAIL A2, BELOW

DETAIL
A1

DETAIL
A2


NOTES:

1) WHEN INSTALLING COMBINATION UNITS, ADDITIONAL INSTALLATION ANCHORS MAY NEED TO BE INSTALLED THROUGH THE WINDOW FRAMES AT 10" MAX. FROM EACH SIDE OF THE FRAME ASSEMBLY TUBE CENTERLINE. SEE TABLE BELOW:

Additional Anchors Required on each Side of the Frame Assembly Tube (FAT)			
Vertical FAT	Window Width	Anchor Type	
		A	B, C & D
	17" - 22.9"	0	0
	23" - 25.9"	0	1
Horizontal FAT	Window Height	Anchor Type	
		A	B, C & D
	17" - 22.9"	0	0
	23" - 25.9"	0	1
Vertical FAT	Window Width	Anchor Type	
		A	B, C & D
	17" - 22.9"	0	0
	23" - 25.9"	0	1
Horizontal FAT	Window Height	Anchor Type	
		A	B, C & D
	17" - 22.9"	0	0
	23" - 25.9"	0	1

VISIBLE LIGHT FORMULAS
WIDTH: WINDOW WIDTH - 7
HEIGHT: WINDOW HEIGHT - 7

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 15-0519.15
Expiration Date April 11, 2018
By *Manuel J. Jorgensen*
Miami Dade Product Control



1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
P.O. BOX 1529
NOKOMIS, FL 34274

CERT. OF AUTH. #29296

Revised By:	Date:	Revision B:
LM	5/15/15	NO CHANGE THIS SHEET

Description:
GENERAL NOTES & ELEVATION



Title:
FIXED CASEMENT WINDOW DETAILS - LM

Series/Model:	Scale:	Sheet:	Drawing No.	Rev:
CA-740	NTS	2 OF 11	MD-CA740F-LM	A

Drawn By:
J ROSOWSKI

Date:
08/08/12

FIXED CASEMENT (O)





FOR SINGLE UNITS:

- 1) DETERMINE YOUR WINDOW SIZE AND GLASS.
- 2) KNOWING YOUR ANCHOR TYPE AND SUBSTRATE, DETERMINE YOUR ANCHOR GROUP FROM TABLE 3, SHEET 4.
- 3) FROM SHEETS 6-10, FIND THE SHEET FOR YOUR GLASS TYPE. FIND THE PRODUCT'S DESIGN PRESSURE FROM THE TABLE LABELED "DESIGN PRESSURE (PSF) FOR SINGLE WINDOWS, ALL ANCHOR GROUPS".
- 4) DIMENSIONS SHOWN ARE TIP-TO-TIP. FOR SIZES NOT SHOWN, ROUND UP TO THE NEXT AVAILABLE WIDTH OR HEIGHT DIMENSION SHOWN ON THE TABLES.
- 5) USING THE TABLES LABELED "WINDOW ANCHORS REQUIRED" (TABLES 2A & 2B, SHEETS 4 & 5), DETERMINE THE NUMBER OF ANCHORS NEEDED IN THE HEAD, SILL AND JAMBS OF YOUR WINDOW.
- 6) INSTALL AS PER THE INSTRUCTIONS ON SHEET 2.

FIXED CASEMENT / CASEMENT (OX)

FIGURE 1:




FOR EACH WINDOW IN A COMBINED ASSEMBLY:


- 1) DETERMINE EACH INDIVIDUAL WINDOW TYPE, SIZE AND GLASS MAKEUP, SEE FIGURES 1 & 2, THIS SHEET. DETERMINE YOUR ANCHOR GROUP FROM TABLE 3, SHEET 4.
- 2) FROM SHEETS 6-10, FIND THE SHEET FOR YOUR GLASS TYPE.
- 3) FIND THE DESIGN PRESSURE FROM THE TABLES LABELED "WINDOW ANCHORS REQUIRED" (TABLES 2A & 2B, SHEETS 4 & 5). THIS MUST BE DONE FOR EACH WINDOW IN THE ASSEMBLY, AND THE LOWEST DESIGN PRESSURE APPLIES TO THE ENTIRE ASSEMBLY. DIMENSIONS SHOWN ARE TIP-TO-TIP. FOR SIZES NOT SHOWN, ROUND UP TO THE NEXT AVAILABLE WIDTH OR HEIGHT DIMENSION SHOWN ON THE TABLES.
- 4) USING THE TABLE LABELED "WINDOW ANCHORS REQUIRED" (TABLES 2A & 2B, SHEETS 4 & 5), DETERMINE THE NUMBER OF ANCHORS NEEDED IN THE HEAD, SILL AND JAMBS OF YOUR WINDOW.
- 5) INSTALL AS PER THE INSTRUCTIONS ON SHEETS 2-3. NOTE THAT ADDITIONAL ANCHORS THROUGH THE WINDOW FRAME INTO THE SUBSTRATE MAY BE REQUIRED (SEE SHEET 2), AND THAT MIN. # 12 X 1" ANCHORS ARE TO BE USED THROUGH THE FRAME INTO THE FRAME ASSEMBLY TUBE (SEE DETAILS ON THIS SHEET).

AWNING / CASEMENT / FIXED CASEMENT (XXO)


FIGURE 2:



*SEE PRODUCT'S NOA FOR INSTALLATION SPECS



VERTICAL SECTION D-D



VERTICAL SECTION E-E

FRAME ASSEMBLY TUBE NOTES:

- 1) DIMENSIONS SHOWN ARE TIP-TO-TIP DIMENSIONS FOR EACH INDIVIDUAL WINDOW. FOR SIZES NOT SHOWN, ROUND UP TO THE NEXT AVAILABLE WIDTH OR HEIGHT DIMENSION SHOWN ON THE TABLES.
- 2) ANY 740-SERIES PRODUCT (CASEMENT, AWNING OR FIXED CASEMENT) MAY BE ATTACHED TO THE FRAME ASSEMBLY TUBE. FOR ALL WINDOWS, USE THE WINDOW'S NOA FOR ANCHORAGE, SIZE AND DESIGN PRESSURE LIMITATIONS.
- 3) ALL WINDOWS IN THE COMBINATION UNIT MUST BE ABLE TO INDIVIDUALLY COMPLY WITH THE REQUIREMENTS OF THEIR RESPECTIVE NOA.
- 4) FRAME ASSEMBLY TUBE TO BE FASTENED TO WINDOW, AS SHOWN IN DETAILS, WITH MIN. #12 X 1" SHEET METAL SCREWS. USE THE SAME SPACING AND QUANTITY AS THE OPPOSITE FRAME MEMBER.
- 5) THE FRAME ASSEMBLY TUBE MAY NOT EXCEED 62" IN LENGTH (AS USED IN A 63" FLANGED WINDOW) OR BE USED IN TEE OR CROSS CONFIGURATIONS.
- 6) THE FRAME ASSEMBLY TUBE IS NOT REQUIRED TO BE CLIPPED TO THE SUBSTRATE. ALL EXTERIOR JOINTS TO BE SEALED BY INSTALLER.
- 7) FOR ALL COMBINATION UNITS, ADDITIONAL INSTALLATION ANCHORS MAY NEED TO BE INSTALLED THROUGH THE WINDOW FRAMES AT 10" MAX. FROM EACH SIDE OF THE FRAME ASSEMBLY TUBE CENTERLINE. SEE TABLE BELOW:

Additional Anchors Required on each Side of the Frame Assembly Tube (FAT)			
Vertical FAT	Window Width	Anchor Type	
		A	B, C & D
	17" - 22.9"	0	0
Horizontal FAT	Window Height	Anchor Type	
		A	B, C & D
	17" - 22.9"	0	0
Horizontal FAT	23" - 25.9"	0	1
	26"+	1	1

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 15-0519.15
Expiration Date April 11, 2018
By *Manuel Perez*
Miami Dade Product Control

Revision A:	NO CHANGE THIS SHEET	Date: 5/15/15	Date: 08/08/12	Revised By: L MILLER	Drawn By: J ROSOWSKI	Description: FRAME ASSEMBLY TUBE DETAILS	Title: FIXED CASEMENT WINDOW DETAILS - LM	Series/Model: CA-740	Scale: NTS	Sheet: 3 OF 11	Rev: A
1070 TECHNOLOGY DRIVE N. VENICE, FL 334275 P.O. BOX 1529 NOKOMIS, FL 34274 CERT. OF AUTH. #29296											





TABLE 2A:

Window Anchors Required (37" and Less on Short Side Dimension)

Anchor Type			Short Side																																
			under 23"				25-15/16"				27-3/4"				29"				31-1/2"				33-1/2"				34"				37"				
			A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	
Long Side	under 23"	Long Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2		
		Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2		
	25-15/16"	Long Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2		
		Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2		
	35"	Long Side	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3		
		Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2		
	37"	Long Side	3	3	3	3	3	3	3	3	3	4	3	3	3	4	3	3	3	4	3	3	3	4	3	3	3	4	3	3	3	4	3	3	
		Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3	4	3	3	
	44"	Long Side	3	4	3	3	3	4	3	3	4	4	3	3	4	5	3	3	4	5	3	3	4	5	3	3	4	5	3	3	4	5	3	3	
		Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3	4	3	3	
	44-1/4"	Long Side	4	5	3	3	4	5	3	3	4	5	3	3	4	5	3	3	4	5	3	3	4	6	3	3	4	6	3	3	3	5	6	3	3
		Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3	4	3	3	
	53-1/8"	Long Side	4	5	3	3	4	5	3	3	5	6	3	3	5	6	3	3	5	6	4	3	5	6	4	3	5	6	4	3	5	7	4	3	
		Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3	4	3	3	
	58"	Long Side	4	6	4	4	5	6	4	4	5	6	4	4	5	6	4	4	5	7	4	4	6	7	4	4	6	7	4	4	6	7	4	4	
		Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3	4	3	3	
	63"	Long Side	5	6	4	4	5	7	4	4	6	7	4	4	6	7	4	4	6	8	4	4	6	8	4	4	6	8	5	4	7	8	5	4	
		Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3	4	3	3	
	66-13/16"	Long Side	5	7	5	5	6	7	5	5	6	7	5	5	6	8	5	5	6	8	5	5	7	8	5	5	7	9	5	5	7	9	5	5	
		Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3	4	3	3	
	67-1/2"	Long Side	5	7	5	5	6	7	5	5	6	8	5	5	6	8	5	5	7	8	5	5	7	9	5	5	7	9	5	5	7	9	5	5	
		Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3	4	3	3	
	68"	Long Side	5	7	5	5	6	7	5	5	6	8	5	5	6	8	5	5	7	8	5	5	7	9	5	5	7	9	5	5	7	9	5	5	
		Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3	4	3	3	
	70"	Long Side	6	7	5	5	6	8	5	5	6	8	5	5	6	8	5	5	7	9	5	5	7	9	5	5	7	9	5	5	8	10	5	5	
		Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3	4	3	3	
	72"	Long Side	6	7	5	5	6	8	5	5	7	8	5	5	7	8	5	5	7	9	5	5	7	9	5	5	7	9	5	5	8	10	6	5	
		Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3	4	3	3	
74"	Long Side	6	7	5	5	6	8	5	5	7	8	5	5	7	9	5	5	7	9	5	5	8	10	5	5	8	10	5	5	8	10	6	5		
	Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3	4	3	3		
76"	Long Side	6	8	5	5	7	8	5	5	7	9	5	5	7	9	5	5	8	10	6	5	8	10	6	5	8	10	6	5	8	11	6	5		
	Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3	4	3	3		
84"	Long Side	7	8	5	5	7	9	5	5	8	10	5	5	8	10	6	5	8	11	6	5	9	11	6	6	9	11	6	6	10	12	7	6		
	Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3	4	3	3		
114"	Long Side	9	12	7	7	10	13	7	7	11	14	8	7	11	14	8	7	12	15	8	8	13	16	9	8	13	16	9	8	14	17	10	9		
	Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3	4	3	3		
134"	Long Side	11	14	8	8	12	15	9	8	13	16	9	8	13	17	9	8	14	18	10	9	15	19	11	10	15	19	11	10						
	Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	3	3	3	3	3	3	3	3	3	3	3	3					
145"	Long Side	12	15	9	9	13	17	9	9	14	18	10	9	15	18	10	9	16	20	11	10														
	Short Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	3	3	3	3														

- 1) USE THIS TABLE FOR ALL WINDOWS PER THE ELEVATIONS ON SHEET 1. DIMENSIONS SHOWN ARE TIP-TO-TIP.
- 2) FOR SIZES NOT SHOWN, ROUND UP TO THE NEXT AVAILABLE SHORT OR LONG SIDE DIMENSION SHOWN ON THE TABLE.
- 3) THE WINDOW'S SHORT AND LONG SIDE MAY BE INVERTED.
- 4) SEE NEXT SHEET FOR ADDITIONAL INFORMATION.

SAMPLE CONFIGURATIONS:



1) OPERABLE (X) WINDOWS MAY BE CASEMENT WINDOWS OR AWNING WINDOWS OF THE SAME SERIES.

TABLE 3:

Group	Anchor	Substrate	Min. Edge Distance	Min. O.C. Distance	Min. Embedment	Anchor Plate Required?
A	#14, steel SMS (G5) or #14, 410 SS SMS	Hollow Block	1"	6"	1-1/4"	No
		S. Pine	5/8"	1"	1-3/8"	No
		6063-T5 Alum.	3/8"	5/8"	.050"	No
		A36 Steel	3/8"	5/8"	.050"	No
		A653 Stud, Gr. 33	3/8"	5/8"	.035", 20 Ga.	No
B	#12, steel SMS (G5) or #12, 410 SS SMS	S. Pine	5/8"	1"	1-3/8"	No
		6063-T5 Alum.	3/8"	5/8"	.050"	No
		A36 Steel	3/8"	5/8"	.050"	No
		A653 Stud, Gr. 33	3/8"	5/8"	.035", 20 Ga.	No
		2.85k Concrete	2-1/2"	4"	1-3/8"	No
C	1/4" steel Ultracon	2.85k Concrete	1"	4"	1-3/4"	No
		Hollow Block	2-1/2"	5"	1-1/4"	No
		S. Pine	5/8"	1"	1-3/8"	Yes
		6063-T5 Alum.	3/8"	5/8"	.0713"	Yes
		A36 Steel	3/8"	5/8"	.050"	Yes
D	1/4" steel Ultracon	A653 Stud, Gr. 33	3/8"	5/8"	.045", 18 Ga.	Yes
		2.85k Concrete	2-1/2"	4"	1-3/4"	Yes
		Hollow Block	2-1/2"	5"	1-1/4"	Yes
		Filled Block	2-1/2"	4"	1-3/4"	Yes
		3.35k Concrete	1"	5"	1-3/4"	No
E	5/16" steel Ultracon	Hollow Block	2-1/2"	5"	1-1/4"	No
		3.5k Concrete	1-1/4"	5"	1-3/4"	No
		Hollow Block	3-1/8"	5"	1-1/4"	No
		Filled Block	2-1/2"	5"	1-3/4"	No
		2.85k Concrete	1"	4"	1-3/4"	Yes



- 1) ANCHOR MUST EXTEND A MINIMUM OF 3 THREADS BEYOND ANY METAL SUBSTRATE.
- 2) ANCHORS MAY BE HEXHEAD, PANHEAD OR FLATHEAD.

TABLE 3: (cont.)

Group	Anchor	Substrate	Min. Edge Distance	Min. O.C. Distance	Min. Embedment	Anchor Plate Required?
D	#14, steel SMS (G5) or #14, 410 SS SMS	S. Pine	5/8"	1"	1-3/8"	Yes
		6063-T5 Alum.	3/8"	5/8"	.0713"	Yes
		A36 Steel	3/8"	5/8"	.050"	Yes
		A653 Stud, Gr. 33	3/8"	5/8"	.045", 18 Ga.	Yes
	1/4" steel Ultracon	2.85k Concrete	1"	4"	1-3/4"	Yes
		2.85k Concrete	2-1/2"	4"	1-3/8"	Yes
		Hollow Block	2-1/2"	5"	1-1/4"	Yes
		Filled Block	2-1/2"	4"	1-3/4"	Yes
	1/4" 410 SS CreteFlex	3.35k Concrete	1"	5"	1-3/4"	No
		Hollow Block	2-1/2"	5"	1-1/4"	No
	5/16" steel Ultracon	3.5k Concrete	1-1/4"	5"	1-3/4"	No
		Hollow Block	3-1/8"	5"	1-1/4"	No
		Filled Block	2-1/2"	5"	1-3/4"	No

TABLE 2B:

Window Anchors Required (Over 37" on Short Side Dimension)

Anchor Type			Short Side																																			
			40"				44"				48-1/4"				53-1/8"				54"				58"				60"				63"				67-1/2"			
			A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D				
Long Side	under 23"	Long Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2			
		Short Side	3	4	3	3	3	4	3	3	4	5	3	3	4	5	3	3	4	5	3	3	4	6	4	4	5	6	4	4	5	7	5	5	5			
	25-15/16"	Long Side	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2	2			
		Short Side	3	4	3	3	3	4	3	3	4	5	3	3	4	5	3	3	4	6	3	3	5	6	4	4	5	6	4	4	5	7	4	4	6	7	5	5
	35"	Long Side	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	3	
		Short Side	3	4	3	3	4	5	3	3	5	6	3	3	5	6	4	3	5	7	4	3	6	7	4	4	6	8	4	4	6	8	5	4	7	9	5	5
	37"	Long Side	3	4	3	3	3	4	3	3	3	4	3	3	3	4	3	3	3	4	3	3	3	4	3	3	3	3	3	3	3	3	3	3	3	3	3	
		Short Side	3	4	3	3	4	5	3	3	5	6	3	3	5	7	4	3	5	7	4	4	6	7	4	4	6	8	4	4	6	8	5	4	7	9	5	5
	44"	Long Side	4	5	3	3	4	5	3	3	4	5	3	3	4	5	3	3	4	5	3	3	4	5	3	3	4	5	3	3	4	5	3	3	3	3	3	
		Short Side	3	4	3	3	4	5	3	3	5	6	3	3	6	7	4	4	6	7	4	4	6	8	5	4	7	8	5	4	7	9	5	5	8	10	6	5
	44-1/4"	Long Side	5	6	3	3	5	6	3	3	5	6	3	3	5	6	3	3	5	6	3	3	5	6	3	3	5	6	3	3	5	6	3	3	5	6	3	3
		Short Side	3	4	3	3	4	5	3	3	5	6	3	3	6	7	4	4	6	7	4	4	7	8	5	4	7	9	5	5	7	9	5	5	8	10	6	5
	53-1/8"	Long Side	5	7	4	4	6	7	4	4	6	7	4	4	6	7	4	4	6	7	4	4	6	7	4	4	6	7	4	4	6	7	4	4	6	7	4	4
		Short Side	3	4	3	3	4	5	3	3	5	6	3	3	6	7	4	4	6	7	4	4	7	8	5	4	7	9	5	5	8	10	5	5	8	11	6	5
	58"	Long Side	6	8	4	4	6	8	5	4	7	8	5	4	7	8	5	4	7	8	5	4	7	8	5	4	7	8	5	4	7	8	5	4	7	8	5	4
		Short Side	3	4	3	3	4	5	3	3	5	6	3	3	6	7	4	4	6	7	4	4	7	8	5	4	7	9	5	5	8	10	6	5	8	11	6	5
	63"	Long Side	7	9	5	4	7	9	5	5	7	9	5	5	8	10	5	5	8	10	5	5	8	10	6	5	8	10	6	5	8	10	6	5	7	9	5	5
		Short Side	3	4	3	3	4	5	3	3	5	6	3	3	6	7	4	4	6	7	4	4	7	8	5	4	7	9	5	5	8	10	6	5	8	11	6	5
	66-13/16"	Long Side	7	9	5	5	8	10	6	5	8	10	6	5	8	11	6	5	8	11	6	5	8	11	6	5	8	11	6	5	8	11	6	5	8	10	6	5
		Short Side	3	4	3	3	4	5	3	3	5	6	3	3	6	7	4	4	6	7	4	4	7	8	5	4	7	9	5	5	8	9	5	5	8	11	6	5
	67-1/2"	Long Side	8	10	5	5	8	10	6	5	8	10	6	5	8	11	6	5	8	11	6	5	8	11	6	5	8	11	6	5	8	11	6	5	8	11	6	5
		Short Side	3	4	3	3	4	5	3	3	5	6	3	3	6	7	4	4	6	7	4	4	7	8	5	4	7	9	5	5	8	9	5	5	8	11	6	5
	68"	Long Side	8	10	5	5	8	10	6	5	8	11	6	5	9	11	6	5	9	11	6	5	9	11	6	5	9	11	6	5	9	11	6	5				
		Short Side	3	4	3	3	4	5	3	3	5	6	3	3	6	7	4	4	6	7	4	4	6	8	5	4	7	9	5	4	7	9	5	5				
	70"	Long Side	8	10	6	5	8	11	6	5	9	11	6	6	9	11	6	6	9	11	6	6	9	11	6	6	9	11	6	6	9	11	6	6				
		Short Side	3	4	3	3	4	5	3	3	5	6	3	3	6	7	4	4	6	7	4	4	6	8	5	4	7	8	5	4	7	9	5	5				
	72"	Long Side	8	10	6	5	9	11	6	6	9	11	6	6	9	11	6	6	9	11	6	6	9	11	6	6	9	11	6	6	9	11	6	6				
		Short Side	3	4	3	3	4	5	3	3	5	6	3	3	6	7	4	4	6	7	4	4	6	8	4	4	7	8	5	4	7	9	5	5				
74"	Long Side	9	11	6	5	9	11	6	6	9	12	7	6	9	12	7	6	9	12	7	6	9	12	7	6	9	12	7	6									
	Short Side	3	4	3	3	4	5	3	3	5	6	3	3	6	7	4	4	6	7	4	4	6	8	4	4	6	8	5	4									
76"	Long Side	9	11	6	6	9	12	7	6	9	12	7	6	9	12	7	6	9	12	7	6	9	12	7	6	9	12	7	6									
	Short Side	3	4	3	3	4	5	3	3	5	6	3	3	6	7	4	3	5	7	4	4	6	8	4	4	6	8	5	4									
84"	Long Side	10	13	7	6	10	13	7	7	10	13	7	7	10	13	7	7	10	13	7	7	10	13	7	7													
	Short Side	3	4	3	3	4	5	3	3	5	6	3	3	6	7	4	3	5	6	4	3																	
114"	Long Side	14	18	10	9																																	
	Short Side	3	4	3	3																																	

AWNING ANCHORS (SEE SEPERATE NOA):

A) FROM TABLE 9, ANCHORS C & D ALLOW A DP OF +70/-90.


B) FOR THE JAMB, FROM TABLE 3, ANCHOR TYPE C HAS THE ANCHOR AND SUBSTRATE DESIRED AND DOES NOT REQUIRE THE ANCHOR PLATE.

C) FROM TABLE 2, 6 ANCHORS ARE REQUIRED IN EACH JAMB.

D) SIMILARLY, 2 ANCHORS ARE REQUIRED IN THE HEAD & SILL.

E) DISTRIBUTE ANCHORS FOLLOWING GUIDELINES FROM ELEVATION ON SHEET 1.

F) PER RULES ON SHEETS 2 & 3, INSTALL 1 ADDITIONAL ANCHOR ON THE FRAME ASSEMBLY TUBE SIDE OF THE AWNING (HEAD & SILL).



FIXED CASEMENT ANCHORS:

A) FROM TABLE 9, ANCHORS C & D ALLOW A DP OF +70/-83.1.

B) FOR THE JAMB, FROM TABLE 3, ANCHOR TYPE C HAS THE ANCHOR AND SUBSTRATE DESIRED AND DOES NOT REQUIRE THE ANCHOR PLATE.

C) FROM TABLE 2B, 5 ANCHORS ARE REQUIRED IN EACH JAMB.

D) SIMILARLY, 3 ANCHORS ARE REQUIRED IN THE HEAD & SILL.

E) DISTRIBUTE ANCHORS FOLLOWING GUIDELINES FROM ELEVATION ON SHEET 1.

F) PER RULES ON SHEET 2, INSTALL 1 ADDITIONAL ANCHOR ON THE FRAME ASSEMBLY TUBE SIDE OF THE FIXED CASEMENT (HEAD & SILL).

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 15-0519-15
Expiration Date 11/11/2018
By *Manuel Lopez*
Miami Dade Product Control

- 1) USE THIS TABLE FOR ALL WINDOWS PER THE ELEVATIONS ON SHEET 1. DIMENSIONS SHOWN ARE TIP-TO-TIP.
- 2) FOR SIZES NOT SHOWN, ROUND UP TO THE NEXT AVAILABLE SHORT OR LONG SIDE DIMENSION SHOWN ON THE TABLE.
- 3) THE WINDOW'S SHORT AND LONG SIDE MAY BE INVERTED.
- 4) SEE NEXT SHEET FOR ADDITIONAL INFORMATION.

Revised By:	L MILLER	Date:	5/15/15	Revision A:	NO CHANGE THIS SHEET
Drawn By:	J ROSOWSKI	Date:	08/08/12		
Description:	ANCHOR TYPE AND QUANTITY				
Title:	FIXED CASEMENT WINDOW DETAILS - LM				
Series/Model:	CA-740	Scale:	NTS	Sheet:	5 OF 11
				Drawing No.:	MD-CA740F-LM
				Rev:	A

1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
P.O. BOX 1529
NOKOMIS, FL 34274
CERT. OF AUTH. #29296

ANTHONY LYNN MILLER
LICENSE
No. 58705
STATE OF FLORIDA
PROFESSIONAL ENGINEER
A. LYNN MILLER, P.E.
P.E. #58705

FOR GLASS TYPES:

1) 5/16" LAMI (1/8 AN - .090" PVB - 1/8 AN)


"PVB"= BUTACITE® PVB INTERLAYER BY KURARAY AMERICA, INC.

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 15-0519.15
Expiration Date April 11, 2018

By *Manuel Perez*
Miami Dade Product Control

TABLE 4:

	Design Pressure (psf) for Single Windows, All Anchor Groups									
	Short Side									
	under 23"	25-15/16"	27-3/4"	33-1/2"	37"	44"	48-1/4"	53-1/8"	58"	63"
Long Side	under 23"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90
	25-15/16"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90
	37"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-84.1	+70/-77	+70/-70.1
	44"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-84.1	+60/-70	+60/-67.8	+60/-61.3
	48-1/4"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-80.1	+60/-70	+60/-63.2	
	53-1/8"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-84.1	+60/-70	+60/-67.5		
	58"	+70/-90	+70/-90	+70/-90	+70/-83.2	+70/-77	+60/-67.8	+60/-63.2		
	63"	+70/-90	+70/-90	+70/-90	+70/-76.5	+70/-70.1	+60/-61.3			
	76"	+70/-90	+70/-84.6	+70/-75.7	+/-58.9	+/-55.6				
	84"	+70/-90	+70/-80.4	+70/-71.3	+/-54.2					




1) SEE SHEETS 1, 4 & 5 FOR WINDOW ANCHOR LOCATIONS AND QUANTITIES.
2) TABLE DIMENSIONS MAY BE ORIENTED VERTICALLY OR HORIZONTALLY AS SHOWN.

TABLE 5:

	Design Pressure (psf) for Windows Attached to a Frame Assembly Tube																							
	Window Dimension "A"																							
	under 23"	25-15/16"	27-3/4"	33-1/2"		37"		44"			48-1/4"			53-1/8"			58"				63"			
	Anchor Group	Anchor Group	Anchor Group	Anchor Group		Anchor Group		Anchor Group			Anchor Group			Anchor Group			Anchor Group				Anchor Group			
	All	All	All	A, C & D	B	A, C & D	B	A	B	C & D	A	B	C & D	A	B	C & D	A	B	C	D	A	B	C	D
Window Dimension "B"	under 23"	+70/-90	+70/-90	+70/-90	+70/-82.1	+70/-90	+70/-74.3	+70/-79.7	+/-62.5	+70/-90	+70/-72.7	+/-56.9	+70/-90	+/-68.1	+/-51.8	+70/-90	+/-60.5	+/-47.4	+70/-87.6	+70/-90	+/-55.7	+/-43.6	+70/-80.7	+70/-89.5
	25-15/16"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-84	+70/-90	+70/-70.7	+70/-90	+70/-90	+/-64.4	+70/-90	+70/-90	+/-58.6	+70/-90	+70/-90	+/-53.6	+70/-84	+70/-90	+70/-90	+/-49.3	+70/-77.3	+70/-90	+70/-90
	37"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-88.4	+70/-90	+70/-84.1	+70/-80.5	+70/-84.1	+70/-77	+70/-73.6	+70/-77	+70/-77	+70/-70.1	+/-67.8	+70/-70.1	+70/-70.1
	44"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-81.6	+70/-90	+70/-84.1	+70/-74.4	+70/-84.1	+60/-70	+60/-67.7	+60/-70	+60/-67.8	+60/-61.9	+60/-67.8	+60/-67.8	+60/-61.3	+/-57	+60/-61.3	+60/-61.3
	48-1/4"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-84.1	+70/-84.1	+70/-84.1	+70/-80.1	+/-67.8	+70/-80.1	+60/-70	+60/-61.7	+60/-70	+60/-63.2	+/-56.4	+60/-63.2	+60/-63.2				
	53-1/8"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-84.1	+70/-84.1	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-67.5	+60/-67.4	+60/-67.5								
	58"	+70/-90	+70/-90	+70/-90	+70/-83.2	+70/-83.2	+70/-77	+70/-77	+60/-67.8	+60/-67.8	+60/-67.8	+60/-63.2	+60/-63.2											
	63"	+70/-90	+70/-90	+70/-90	+70/-76.5	+70/-76.5	+70/-70.1	+70/-70.1	+60/-61.3	+60/-61.3	+60/-61.3													
	76"	+70/-90	+70/-84.6	+70/-75.7	+/-58.9	+/-58.9	+/-55.6																	
	84"	+70/-90	+70/-80.4	+70/-71.3	+/-54.2	+/-54.2																		


1) THE WINDOW'S WIDTH AND HEIGHT MAY BE INVERTED.

FIGURE FOR VERTICAL FRAME ASSEMBLY TUBE



SEE SHEETS 1, 4 & 5 FOR WINDOW ANCHOR LOCATIONS AND QUANTITIES. SEE SHEET 3 FOR ANY ADDITIONAL ANCHORS REQUIRED FOR THE FRAME ASSEMBLY TUBE.

FIGURE FOR HORIZONTAL FRAME ASSEMBLY TUBE



SEE SHEETS 1, 4 & 5 FOR WINDOW ANCHOR LOCATIONS AND QUANTITIES. SEE SHEET 3 FOR ANY ADDITIONAL ANCHORS REQUIRED FOR THE FRAME ASSEMBLY TUBE.

Revision A:
NO CHANGE THIS SHEET

Date: 5/15/15
Revised By: L MILLER

Date: 08/08/12
Drawn By: J ROSOWSKI

Description:
DESIGN PRESSURES PER GLAZING TYPE

Title:
FIXED CASEMENT WINDOW DETAILS - LM

Scale:
NTS

Sheet:
6 OF 11

Drawing No.
MD-CA740F-LM

Series/Model:
CA-740

CERT. OF AUTH. #29296

ANTHONY LYNN MILLER
LICENSE
No. 58705
STATE OF
FLORIDA
PROFESSIONAL ENGINEER
ANTHONY LYNN MILLER, P.E.
P.E.# 58705

FOR GLASS TYPES:


5) 7/8" LAMI. IG:(1/8" T - 7/16" AIR - 1/8" AN - .090" PVB - 1/8" AN)

PVB= BUTACITE® PVB INTERLAYER BY KURARAY AMERICA, INC.

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. **15-058-15**
Expiration Date **APR 11, 2018**
By *Manuel Perez*
Miami Dade Product Control

TABLE 6:

Design Pressure (psf) for Single Windows, All Anchor Groups											
Long Side	Short Side										
	under 23"	25-15/16"	27-3/4"	33-1/2"	37"	44"	48-1/4"	53-1/8"	58"	63"	
	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	
	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	
	37"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-87.8	+70/-79.9	
	44"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90				
	48-1/4"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90				
	53-1/8"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90					
	58"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-87.8					
	63"	+70/-90	+70/-90	+70/-90	+70/-87.2	+70/-79.9					
	76"	+70/-90	+70/-90	+70/-86.3							
	84"	+70/-90	+70/-90	+70/-81.3							




- 1) SEE SHEETS 1, 4 & 5 FOR WINDOW ANCHOR LOCATIONS AND QUANTITIES.
- 2) TABLE DIMENSIONS MAY BE ORIENTED VERTICALLY OR HORIZONTALLY AS SHOWN.

TABLE 7:

Design Pressure (psf) for Windows Attached to a Frame Assembly Tube																								
Window Dimension "B"	Window Dimension "A"																							
	under 23"	25-15/16"	27-3/4"	33-1/2"		37"		44"			48-1/4"			53-1/8"			58"				63"			
	Anchor Group	Anchor Group	Anchor Group	Anchor Group		Anchor Group		Anchor Group			Anchor Group			Anchor Group			Anchor Group				Anchor Group			
	All	All	All	A, C & D	B	A, C & D	B	A	B	C & D	A	B	C & D	A	B	C & D	A	B	C	D	A	B	C	D
	under 23"	+70/-90	+70/-90	+70/-90	+70/-82.1	+70/-90	+70/-74.3	+70/-79.7	+/-62.5	+70/-90	+70/-72.7	+/-56.9	+70/-90	+/-66.1	+/-51.8	+70/-90	+/-60.5	+/-47.4	+70/-87.8	+70/-90	+/-55.7	+/-43.6	+70/-80.7	+70/-89.5
	25-15/16"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-84	+70/-90	+70/-70.7	+70/-90	+70/-90	+/-64.4	+70/-90	+/-58.6	+70/-90	+/-53.6	+70/-84	+70/-90	+70/-84	+70/-90	+70/-90	+/-49.3	+70/-77.3	+70/-90	+70/-90
37"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-88.4	+70/-90	+70/-90	+70/-80.5	+70/-90	+70/-87.8	+70/-73.6	+70/-87.8	+70/-87.8	+70/-79.9	+/-67.8	+70/-79.9	+70/-79.9
44"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-81.6	+70/-90	+70/-90	+70/-74.4	+70/-90											
48-1/4"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-89.2	+70/-90	+70/-86.5	+70/-81.3	+70/-90											
53-1/8"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90																	
58"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-87.8	+70/-87.8																	
63"	+70/-90	+70/-90	+70/-90	+70/-87.2	+70/-87.2	+70/-79.9	+70/-79.9																	
76"	+70/-90	+70/-90	+70/-86.3																					
84"	+70/-90	+70/-90	+70/-81.3																					


1) THE WINDOW'S WIDTH AND HEIGHT MAY BE INVERTED.

FIGURE FOR VERTICAL FRAME ASSEMBLY TUBE



SEE SHEETS 1, 4 & 5 FOR WINDOW ANCHOR LOCATIONS AND QUANTITIES. SEE SHEET 3 FOR ANY ADDITIONAL ANCHORS REQUIRED FOR THE FRAME ASSEMBLY TUBE.

FIGURE FOR HORIZONTAL FRAME ASSEMBLY TUBE



SEE SHEETS 1, 4 & 5 FOR WINDOW ANCHOR LOCATIONS AND QUANTITIES. SEE SHEET 3 FOR ANY ADDITIONAL ANCHORS REQUIRED FOR THE FRAME ASSEMBLY TUBE.

SEE SHEET 4 FOR ADDITIONAL SAMPLE CONFIGURATIONS

Revision A: NO CHANGE THIS SHEET

Date: 5/15/15

Revised By: L MILLER

Date: 08/08/12

Drawn By: J ROSOWSKI

Description: DESIGN PRESSURES PER GLAZING TYPE

Title: FIXED CASEMENT WINDOW DETAILS - LM

Scale: NTS

Sheet: 7 OF 11

Series/Model: CA-740

MD-CA740F-LM

1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
P.O. BOX 1529
NOKOMIS, FL 34274

CERT. OF AUTH. #29296

FOR GLASS TYPES:


- 2) 7/16" LAMI. (3/16" AN - .090" SG - 3/16" AN
 6) 7/8" LAMI. IG: (3/16" AN - 1/4" AIR - 3/16" AN - .090" SG - 3/16" AN)
 8) 7/8" LAMI. IG: (3/16" T - 1/4" AIR - 3/16" AN - .090" SG - 3/16" AN)

"SG"= SENTRYGLAS® INTERLAYER BY KURARAY AMERICA, INC.

PRODUCT REVISED
 as complying with the Florida
 Building Code
 Acceptance No. **15-0519-15**
 Expiration Date **April 11, 2018**
 By *Manuel Perez*
 Miami Dade Product Control

TABLE 8:

		Design Pressure (psf) for Single Windows, All Anchor Groups									
Long Side	Short Side	under 23"	25-15/16"	29"	31-1/2"	34"	40"	54"	60"	63"	67-1/2"
		+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130
		+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130
		+90/-130	+90/-130	+90/-123.1	+90/-116.5	+90/-110.7	+90/-100.7	+/- 89.1	+/- 86.1	+/- 83.1	+/- 78.3
		+90/-130	+90/-130	+90/-120.7	+90/-113.9	+90/-108	+90/-97.6	+/- 84.8	+/- 80.5	+/- 78.3	+/- 75.1
		+90/-130	+90/-129.2	+90/-118.7	+90/-111.8	+90/-105.8	+90/-95.1	+/- 81.3	+/- 76.1	+/- 73.8	
		+90/-130	+90/-127.8	+90/-117.1	+90/-110.2	+90/-104.1	+90/-93.2	+/- 78	+/- 72.5		
		+90/-130	+90/-125.3	+90/-114.5	+90/-107.5	+90/-101.3	+/- 89.9	+/- 70.7			
		+90/-130	+90/-119.6	+90/-108.6	+90/-101.4	+90/-95	+/- 73				
		+90/-130	+90/-117.3	+90/-106.3	+90/-99	+90/-92.6					
		+90/-129.8	+90/-116.4	+90/-105.3	+90/-98						




- 1) SEE SHEETS 1, 4 & 5 FOR WINDOW ANCHOR LOCATIONS AND QUANTITIES.
 2) TABLE DIMENSIONS MAY BE ORIENTED VERTICALLY OR HORIZONTALLY AS SHOWN.

TABLE 9:

		Design Pressure (psf) for Windows Attached to a Frame Assembly Tube																				
		Window Dimension "A"																				
		under 23"	25-15/16"	29"	31-1/2"		34"		40"			54"			60"				63"			
		Anchor Group	Anchor Group	Anchor Group	Anchor Group		Anchor Group		Anchor Group			Anchor Group			Anchor Group				Anchor Group			
		All	All	All	A, C & D	B	A, C & D	B	A	B	C & D	A	B	C & D	A	B	C	D	A	B	C	D
Window Dimension "B"	under 23"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-87.4	+70/-90	+70/-80.8	+70/-87.7	+/-68.7	+70/-90	+/-65	+/-50.9	+70/-90	+/-58.5	+/-45.8	+70/-84.7	+70/-90	+/-55.7	+/-43.6	+70/-80.7	+70/-89.5
	25-15/16"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-77.7	+70/-90	+70/-90	+/-57.6	+70/-90	+70/-90	+/-51.8	+70/-81.2	+70/-90	+70/-90	+/-49.3	+70/-77.3	+70/-90	+70/-90
	63"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-83	+70/-74.3	+70/-89.1	+70/-74.7	+/-66.9	+70/-86.1	+70/-86.1	+70/-71.1	+/-63.7	+70/-83.1	+70/-83.1
	67-1/2"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-77.4	+/-69.3	+70/-84.8	+/-69.7	+/-62.4	+70/-80.5	+70/-80.5	+/-66.4	+/-59.4	+70/-78.3	+70/-78.3
	72"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-72.6	+70/-73.1	+70/-81.3	+/-65.3	+/-65.8	+70/-76.1	+70/-76.1	+/-62.2	+/-55.7	+70/-73.8	+70/-73.8
	76"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-78	+/-69.3	+70/-78	+/-61.9	+/-62.4	+70/-72.5	+70/-72.5				
	84"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-89.9	+70/-89.9	+70/-89.9	+70/-70.7	+/-62.7	+70/-70.7								
	114"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-73	+70/-73	+70/-73											
	134"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90														
	145"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90																


1) THE WINDOW'S WIDTH AND HEIGHT MAY BE INVERTED.

FIGURE FOR VERTICAL FRAME ASSEMBLY TUBE




SEE SHEETS 1, 4 & 5 FOR WINDOW ANCHOR LOCATIONS AND QUANTITIES. SEE SHEET 3 FOR ANY ADDITIONAL ANCHORS REQUIRED FOR THE FRAME ASSEMBLY TUBE.

FIGURE FOR HORIZONTAL FRAME ASSEMBLY TUBE




SEE SHEETS 1, 4 & 5 FOR WINDOW ANCHOR LOCATIONS AND QUANTITIES. SEE SHEET 3 FOR ANY ADDITIONAL ANCHORS REQUIRED FOR THE FRAME ASSEMBLY TUBE.

Revision A:	NO CHANGE THIS SHEET	Date:	5/15/15	Date:	08/08/12	Revised By:	L MILLER	Drawn By:	J ROSOWSKI	Description:	DESIGN PRESSURES PER GLAZING TYPE	Title:	FIXED CASEMENT WINDOW DETAILS - LM	Series/Model:	CA-740	Scale:	NTS	Sheet:	8 OF 11	Drawing No.:	MD-CA740F-LM	Rev:	A
-------------	----------------------	-------	---------	-------	----------	-------------	----------	-----------	------------	--------------	-----------------------------------	--------	------------------------------------	---------------	--------	--------	-----	--------	---------	--------------	--------------	------	---




1070 TECHNOLOGY DRIVE
 N. VENICE, FL 34275
 P.O. BOX 1529
 NOKOMIS, FL 34274
 CERT. OF AUTH. #29296



FOR GLASS TYPES:

- 3) 7/16" LAMI (3/16 HS - .090" SG - 3/16 HS)
- 7) 7/8" LAMI IG: 3/16" AN - 1/4" AIR - 3/16" HS - .090" SG - 3/16" HS)
- 9) 7/8" LAMI IG: (3/16" T - 1/4" AIR - 3/16" HS - .090" SG - 3/16" HS)

"SG"= SENTRYGLAS® INTERLAYER BY KURARAY AMERICA, INC.



- 1) SEE SHEETS 1, 4 & 5 FOR WINDOW ANCHOR LOCATIONS AND QUANTITIES.
- 2) TABLE DIMENSIONS MAY BE ORIENTED VERTICALLY OR HORIZONTALLY AS SHOWN.

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. **15-0519.15**
Expiration Date **SEP 11, 2018**
By *Manuel Perez*
Miami Dade Product Control

TABLE 10:


Design Pressure (psf) for Single Windows, All Anchor Groups										
Long Side	Short Side									
	under 23"	25-15/16"	29"	31-1/2"	34"	40"	54"	60"	63"	67-1/2"
	under 23"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130
	25-15/16"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130
	63"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130
	67-1/2"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130
	72"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	
	76"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	
	84"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130			
	114"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130				
	134"	+90/-130	+90/-130	+90/-130	+90/-130	+90/-130				
	145"	+90/-130	+90/-130	+90/-130	+90/-130					

TABLE 11:

Design Pressure (psf) for Windows Attached to a Frame Assembly Tube																					
Window Dimension "B"	Window Dimension "A"																				
	under 23"	25-15/16"	29"	31-1/2"		34"		40"			54"			60"				63"			
	Anchor Group	Anchor Group	Anchor Group	Anchor Group		Anchor Group		Anchor Group			Anchor Group			Anchor Group				Anchor Group			
	All	All	All	A, C & D	B	A, C & D	B	A	B	C & D	A	B	C & D	A	B	C	D	A	B	C	D
	under 23"	+70/-90	+70/-90	+70/-90	+70/-87.4	+70/-90	+70/-80.8	+70/-87.7	+/-68.7	+70/-90	+/-65	+/-50.9	+70/-90	+/-58.5	+/-45.8	+70/-84.7	+70/-90	+/-55.7	+/-43.6	+70/-80.7	+70/-89.5
	25-15/16"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-77.7	+70/-90	+70/-90	+/-57.6	+70/-90	+70/-90	+/-51.8	+70/-81.2	+70/-90	+70/-90	+/-49.3	+70/-77.3	+70/-90	+70/-90
	63"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-87.6	+70/-90	+70/-90
	67-1/2"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-89.1	+70/-90	+70/-90
	72"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90
	76"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90
	84"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90				
	114"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90											
	134"	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90	+70/-90														
	145"	+70/-90	+70/-90	+70/-90	+70/-90																


1) THE WINDOW'S WIDTH AND HEIGHT MAY BE INVERTED.

FIGURE FOR VERTICAL FRAME ASSEMBLY TUBE



SEE SHEETS 1, 4 & 5 FOR WINDOW ANCHOR LOCATIONS AND QUANTITIES. SEE SHEET 3 FOR ANY ADDITIONAL ANCHORS REQUIRED FOR THE FRAME ASSEMBLY TUBE.

FIGURE FOR HORIZONTAL FRAME ASSEMBLY TUBE



SEE SHEETS 1, 4 & 5 FOR WINDOW ANCHOR LOCATIONS AND QUANTITIES. SEE SHEET 3 FOR ANY ADDITIONAL ANCHORS REQUIRED FOR THE FRAME ASSEMBLY TUBE.

Revised By:	L MILLER	Date:	5/15/15	Revision A:	NO CHANGE THIS SHEET
Drawn By:	J ROSOWSKI	Date:	08/08/12		
Description:	DESIGN PRESSURES PER GLAZING TYPE				
Title:	FIXED CASEMENT WINDOW DETAILS - LM				
Series/Model:	CA-740	Scale:	NTS	Sheet:	9 OF 11
				Drawing No.	MD-CA740F-LM

PG
1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
P.O. BOX 1529
NOKOMIS, FL 34274
CERT. OF AUTH. #29296

ANTHONY LYNN MILLER
LICENSE
No. 58705
7/16/15
STATE OF
FLORIDA
PROFESSIONAL ENGINEER
A. LYNN MILLER, P.E.
P.E. # 58705

FOR GLASS TYPES:


4) 7/8" LAMI. IG:(1/8" AN - 7/16" AIR - 1/8" AN - .090" PVB - 1/8" AN)

"PVB"= BUTACITE® PVB INTERLAYER BY KURARAY AMERICA, INC.

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 15-0519-15
Expiration Date April 11, 2018
By *Manuel Piza*
Miami Dade Product Control

TABLE 12:

	Design Pressure (psf) for Single Windows, All Anchor Groups									
	Short Side									
	under 23"	25-15/16"	27-3/4"	33-1/2"	37"	44"	48-1/4"	53-1/8"	58"	63"
Long Side	under 23"	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70
	25-15/16"	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70
	37"	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70
	44"	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-69.6	+60/-62.9
	48-1/4"	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-64.9	
	53-1/8"	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-69.3		
	58"	+60/-70	+60/-70	+60/-70	+60/-70	+60/-69.6	+60/-64.9			
	63"	+60/-70	+60/-70	+60/-70	+60/-70	+60/-62.9				
	76"	+60/-70	+60/-70	+60/-70	+60/-60.5	+/- 57				
	84"	+60/-70	+60/-70	+60/-70	+/- 55.6					




- 1) SEE SHEETS 1, 4 & 5 FOR WINDOW ANCHOR LOCATIONS AND QUANTITIES.
- 2) TABLE DIMENSIONS MAY BE ORIENTED VERTICALLY OR HORIZONTALLY AS SHOWN.

TABLE 13:

	Design Pressure (psf) for Windows Attached to a Frame Assembly Tube																		
	Window Dimension "A"																		
	under 23"	25-15/16"	27-3/4"	33-1/2"	37"	44"		48-1/4"			53-1/8"			58"			63"		
	Anchor Group	Anchor Group	Anchor Group	Anchor Group	Anchor Group	Anchor Group		Anchor Group			Anchor Group			Anchor Group			Anchor Group		
	All	All	All	All	All	A, C & D	B	A	B	C & D	A	B	C & D	A	B	C & D	A	B	C & D
Window Dimension "B"	under 23"	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-62.5	+60/-70	+/-56.9	+60/-70	+60/-66.1	+/-51.8	+60/-70	+60/-60.5	+/-47.4	+60/-70	+/-55.7	+/-43.6	+60/-70
	25-15/16"	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-64.4	+60/-70	+60/-70	+/-58.6	+60/-70	+60/-70	+/-53.6	+60/-70	+60/-70	+/-49.3	+60/-70	+60/-70
	37"	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-67.8	+60/-70
	44"	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-67.7	+60/-70	+60/-69.6	+60/-61.9	+60/-69.6	+60/-62.9	+/-57	+60/-62.9
	48-1/4"	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-67.8	+60/-70	+60/-70	+60/-61.7	+60/-70	+60/-64.9	+/-56.4	+60/-64.9			
	53-1/8"	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-69.3	+60/-67.4	+60/-69.3						
	58"	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-69.6	+60/-69.6	+60/-64.9	+60/-64.9									
	63"	+60/-70	+60/-70	+60/-70	+60/-70	+60/-70	+60/-62.9	+60/-62.9											
	76"	+60/-70	+60/-70	+60/-70	+60/-70	+60/-60.5	+/-57												
	84"	+60/-70	+60/-70	+60/-70	+/-55.6														


1) THE WINDOW'S WIDTH AND HEIGHT MAY BE INVERTED.

FIGURE FOR VERTICAL FRAME ASSEMBLY TUBE




SEE SHEETS 1, 4 & 5 FOR WINDOW ANCHOR LOCATIONS AND QUANTITIES. SEE SHEET 3 FOR ANY ADDITIONAL ANCHORS REQUIRED FOR THE FRAME ASSEMBLY TUBE.

FIGURE FOR HORIZONTAL FRAME ASSEMBLY TUBE





SEE SHEETS 1, 4 & 5 FOR WINDOW ANCHOR LOCATIONS AND QUANTITIES. SEE SHEET 3 FOR ANY ADDITIONAL ANCHORS REQUIRED FOR THE FRAME ASSEMBLY TUBE.

Revised By: L MILLER	Date: 5/15/15	Revision A: NO CHANGE THIS SHEET
Drawn By: J ROSOWSKI	Date: 08/08/12	
Description: DESIGN PRESSURES PER GLAZING TYPE		
Title: FIXED CASEMENT WINDOW DETAILS - LM		
Series/Model: CA-740	Scale: NTS	Sheet: 10 OF 11
		Rev: MD-CA740F-LM A



1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
P.O. BOX 1529
NOKOMIS, FL 34274
CERT. OF AUTH. #29296







ASSEMBLY DETAILS

TABLE 19:


Item	Dwg. #	Description	Mat.
1	7005	Main Frame Head, Sill & Jambs	6063-T6 Alum.
2	7071	Anchor Plate	6063-T6 Alum.
3	7007	Installation Hole Cover	6063-T6 Alum.
4	7010	Frame Corner Key	Steel
6	7078	Frame Gasket	Vinyl Foam
10	7055	Fixed Frame Hole Plug	PVC
31		DuraSeal Spacer	
32	1713	Setting Block 5/32" x 3/16" x 1-1/4"	EPDM
33	1714	Setting Block 5/32" x 1-7/16" x 1-1/4"	EPDM
35	7036	Bead B	6063-T6 Alum.
36	7042	Bead C	6063-T6 Alum.
37	7059	Bead D	6063-T6 Alum.
38	1224	Vinyl Bulb Wstp (Thick)	Flex PVC 70
39	1225	Vinyl Bulb Wstp (Thin)	Flex PVC 70
50		Dow 899 Silicon Backbedding	
70	134	Add-on Flange	6063-T6 Alum.
71	7004	Casement Frame Assy Tube	6063-T6 Alum.
86		#8 X 1-1/2" Quad Pn SMS Stainless Steel	Stainless Steel
90		#12 x 1" Ph. Pn. TEK	Stainless Steel




1 FRAME HEAD, SILL & JAMB
#7005, 6063-T6




71 FRAME ASSEMBLY TUBE
#7004, 6063-T6




3 INST. HOLE COVER
#7007, 6063-T6




2 ANCHOR PLATE
#7071, 6063-T6




70 ADDON FLANGE
#134, 6063-T6




35 BEAD B
#7036, 6063-T6



36 BEAD C
#7042, 6063-T6



37 BEAD D
#7059, 6063-T6



1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
P.O. BOX 1529
NOKOMIS, FL 34274

CERT. OF AUTH. #29296

Revised By:	Date:	Revision B:
LM	5/15/15	NO CHANGE THIS SHEET
Description: BOM AND EXTRUSIONS		
Title: FIXED CASEMENT WINDOW DETAILS - LM		Date: 08/08/12
Series/Model: CA-740	Scale: NTS	Sheet: 11 OF 11
Drawing No. MD-CA740F-LM	Rev: A	

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 15-0519.15
Expiration Date April 11, 2018
By: *Mamuel Perez*
Miami Dade Product Control

Drawn By:
J ROSOWSKI