



DEPARTMENT OF REGULATORY AND ECONOMIC RESOURCES (RER)
BOARD AND CODE ADMINISTRATION DIVISION
NOTICE OF ACCEPTANCE (NOA)

PGT Industries, Inc.
1070 Technology Drive
North Venice, FL 34275

SCOPE:

This NOA is being issued under the applicable rules and regulations governing the use of construction materials. The documentation submitted has been reviewed and accepted by Miami-Dade County RER -Product Control Section to be used in Miami Dade County and other areas where allowed by the Authority Having Jurisdiction (AHJ).

This NOA shall not be valid after the expiration date stated below. The Miami-Dade County Product Control Section (In Miami Dade County) and/or the AHJ (in areas other than Miami Dade County) reserve the right to have this product or material tested for quality assurance purposes. If this product or material fails to perform in the accepted manner, the manufacturer will incur the expense of such testing and the AHJ may immediately revoke, modify, or suspend the use of such product or material within their jurisdiction. RER reserves the right to revoke this acceptance, if it is determined by Miami-Dade County Product Control Section that this product or material fails to meet the requirements of the applicable building code.

This product is approved as described herein, and has been designed to comply with the Florida Building Code, including the High Velocity Hurricane Zone.

DESCRIPTION: Series "SGD-780" Aluminum Sliding Glass Door w/90° & 135° corner (Reinf/Non-Reinf)– **L.M.I.**

APPROVAL DOCUMENT: Drawing No. **MD-780.0 Rev A**, titled "Aluminum Sliding Glass Door (LM)", sheets 1 through 18 of 18, dated 10/05/15 and last revised on 06/08/16, prepared by PGT Industries, signed and sealed by Anthony Lynn Miller, P. E., bearing the Miami-Dade County Product Control Revision stamp with the Notice of Acceptance number and Expiration date by the Miami-Dade County Product Control Section.

MISSILE IMPACT RATING: Large and Small Missile Impact Resistant

Limitations:

1. Max Panels configuration is allowed per tables 1 thru 3, not to exceed 462.11 ft². The inside/outside 90° & 135° corner units are limited to straight panel each corner side per tables 1 thru 3.
2. See sheets 7 & 8 for Design Pressure (DP), glass type, sill type for positive DP limit, applicable reinforcement and anchorage quantity requirements. See sheets 12 thru 15 for anchors lay out at tracks and corners. See Pocket anchor details in sheet 6.
3. Pockets wall, cavity are not part of this approval. Exterior/Interior Pocket wall & applicable Egress requirement to be reviewed by Building official.

LABELING: Each unit shall bear a permanent label with the manufacturer's name or logo, city, state and series and following statement: "Miami-Dade County Product Control Approved", noted herein.

RENEWAL of this NOA shall be considered after a renewal application has been filed and there has been no change in the applicable building code negatively affecting the performance of this product.

TERMINATION of this NOA will occur after the expiration date or if there has been a revision or change in the materials, use, and/or manufacture of the product or process. Misuse of this NOA as an endorsement of any product, for sales, advertising or any other purposes shall automatically terminate this NOA. Failure to comply with any section of this NOA shall be cause for termination and removal of NOA.

ADVERTISEMENT: The NOA number preceded by the words Miami-Dade County, Florida, and followed by the expiration date may be displayed in advertising literature. If any portion of the NOA is displayed, then it shall be done in its entirety.

INSPECTION: A copy of this entire NOA shall be provided to the user by the manufacturer or its distributors and shall be available for inspection at the job site at the request of the Building Official.

This NOA revises NOA #15-0903.09 and consists of this page 1 and evidence pages E-1 & E-2, as well as approval document mentioned above.

The submitted documentation was reviewed by **Ishaq I. Chanda, P.E.**

MIAMI-DADE COUNTY
APPROVED

NOA No. 16-0629.10
Expiration Date: August 02, 2017
Approval Date: August 11, 2016
Page 1

8/11/16

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

A. DRAWINGS

1. Manufacturer's die drawings and sections (Submitted under files # listed below)
2. Drawing No. **MD-780.0 Rev A**, titled "Aluminum Sliding Glass Door (LM)", sheets 1 through 18 of 18, dated 10/05/15 and last revised on 06/08/16, prepared by PGT Industries, signed and sealed by Anthony Lynn Miller, P.E.

B. TESTS

1. REF Test report on 1) Uniform Static Air Pressure Test, per FBC, TAS 202-94
2) Large Missile Impact Test per FBC, TAS 201-94
3) Cyclic Wind Pressure Loading per FBC, TAS 203-94

Along with marked-up drawings and installation diagram of Aluminum Sliding Glass Doors (w/ TPS, Super, Cardinal & Duraseal Spacers), prepared by Fenestration Testing Laboratory, Inc., Test Reports No(s) **FTL-8717**, **FTL-8970** and **FTL-8968**, dated 02/15/16, 06/07/16 and 06/20/16, all signed & sealed by Idalmis Ortega, P.E

2. Test reports on: 1) Air Infiltration Test, per FBC, TAS 202-94
2) Uniform Static Air Pressure Test, Loading per FBC TAS 202-94
3) Water Resistance Test, per FBC, TAS 202-94
4) Large Missile Impact Test per FBC, TAS 201-94
5) Cyclic Wind Pressure Loading per FBC, TAS 203-94
6) Forced Entry Test, per FBC 2411 3.2.1, TAS 202-94

Along with marked-up drawings and installation diagram of Aluminum SGD w/135⁰ interior/Exterior corner & interior pocket mount, prepared by Fenestration Testing Laboratory, Inc., Test Reports No(s) **FTL-8322** and **FTL-8374**, dated 08/06/15, both signed and sealed by Idalmis Ortega, P. E. (Addendum letter dated Jan 18, 2016, issued by Fenestration Testing Lab)

Along with marked-up drawings and installation diagram of Aluminum SGD, prepared by Architectural Testing, Inc., Test Report No. **ATI-8124.01-401-18 R**, dated 11/13/2008, signed and sealed by Joseph A. Reed, P.E. (submitted under files #**15-0903.09**/**12-0516.04**)


Along with marked-up drawings and installation diagram of Aluminum SGD, prepared by Fenestration Testing Laboratory, Inc., Test Reports No(s) **FTL-5618**, dated 06/21/2008, **FTL-5619**, dated 07/07/2008, **FTL-5254**, dated 05/17/2007 and **FTL-5273**, dated 05/07/2007 respectively, all signed and sealed by Carlos S. Rionda, P. E.(Submitted under file #**11-1018.12**)

C. CALCULATIONS (submitted under files #15-0903.09)

1. Anchor verification calculations and structural analysis dated 01/20/16, complying with FBC-2014 (5th Edition), prepared by PGT, signed and sealed by Lynn Miller, P.E.
2. Glazing complies w/ ASTM E-1300-02, 04 & -09.

D. QUALITY ASSURANCE

1. Miami Dade Department of Regulatory and Economic Resources (RER).


Ishaq I. Chanda, P.E.
Product Control Examiner
NOA No. 16-0629.10
Expiration Date: August 02, 2017
Approval Date: August 11, 2016

NOTICE OF ACCEPTANCE: EVIDENCE SUBMITTED

E. MATERIAL CERTIFICATIONS

1. Notice of Acceptance No. **14-0916.11** issued to **Kuraray America, Inc.** (Former E.I. DuPont DeNemours & Co., Inc.) for the “**Sentry Glass ® (Clear and White) Glass Interlayers**”, expiring on 07/04/18.
2. Notice of Acceptance No. **14-0916.10** issued to **Kuraray America, Inc.** (Former E.I. DuPont DeNemours & Co., Inc.) for the “**Kurray Butacite PVB Interlayers**”, expiring on 12/11/2016.

F. STATEMENTS

1. Statement letter of conformance to FBC 2014(5th edition) and letter of no financial interest, prepared by PGT, dated 08/28/15, signed and sealed by Lynn Miller, P.E.(submitted under files #15-0903.09)
2. Spacer reference e-mail by PGT dated Jan 13, 2016, signed by Lynn Miller, P.E.
3. Lab compliance as part of the above referenced test report.

G. OTHER

1. This NOA **revises** NOA #15-0903.09, expiring 08/02/17.
2. Test proposal # **16-0152** dated 03/09/16, #**14-1739**, Test proposals No(s) **09-0177, 0177-A, B & C** and approved by RER and Test proposal # **07-2583**, approved by BCCO.
3. AAMA's Technical Paper for SGD & Bi-fold doors referenced to FBC 2014 (5th edition).



Ishfaq I. Chanda, P.E.

Product Control Examiner

NOA No. 16-0629.10

Expiration Date: August 02, 2017

Approval Date: August 11, 2016

SERIES 780, IMPACT RESISTANT SLIDING GLASS DOOR
INCLUDING POCKETS & 90°/135° CORNERS

GENERAL NOTES

- 1) GLAZING TYPE OPTIONS: SEE TABLE B, THIS SHEET & GLAZING DETAILS ON SHEET 11.
2) DESIGN PRESSURES:
A. NEGATIVE DESIGN LOADS BASED ON TESTED PRESSURE AND GLASS TABLES ASTM E1300.
B. POSITIVE DESIGN LOADS BASED ON WATER TEST PRESSURE AND GLASS TABLES ASTM E1300.
3) ANCHORAGE: THE 33-1/3% STRESS INCREASE HAS NOT BEEN USED IN THE DESIGN OF THIS PRODUCT. MATERIALS, INCLUDING BUT NOT LIMITED TO STEEL SCREWS, THAT COME INTO CONTACT WITH OTHER DISSIMILAR MATERIALS SHALL MEET THE REQUIREMENTS OF THE CURRENT FLORIDA BUILDING CODE.
4) SHUTTERS ARE NOT REQUIRED PER FBC REQUIREMENTS, AS APPLICABLE.
5) INSTALLATION SCREWS, FRAME SPLICES, FRAME AND PANEL CORNERS TO BE SEALED WITH NARROW JOINT SEALANT.
6) REFERENCES: ELCO ULTRACON, CRETEFLEX AND AGGREGATOR NOA'S, ANSI/AF&PA NDS FOR WOOD CONSTRUCTION AND ADM, ALUMINUM DESIGN MANUAL.
7) THIS PRODUCT HAS BEEN DESIGNED & TESTED TO COMPLY WITH THE REQUIREMENTS OF THE CURRENT FLORIDA BUILDING CODE, INCLUDING THE HIGH VELOCITY HURRICANE ZONE (HVHZ).
8) DOOR SIZES MUST BE VERIFIED FOR COMPLIANCE WITH EGRESS REQUIREMENTS PER THE CURRENT FLORIDA BUILDING CODE, AS APPLICABLE.
9) APPLICABLE TEST REPORTS: FTL-5254, 5273, 5618, 5619, 8322, 8374 & ATI-81241.01-401-18.

TABLE B: SEE DETAILS ON SHEET 11

Glass Type	Description (Listed from Exterior to Interior)	Table #	Sheet #
1	7/16" Laminated: (1) Lite of 3/16" ANN Glass and (1) Lite of 3/16" HS Glass with .090" PVB Interlayer	2	7
2	9/16" Laminated: (1) Lite of 1/4" ANN Glass and (1) Lite of 1/4" HS Glass with .090" PVB Interlayer	2	7
3	1-1/16" Laminated I.G.: 3/16" T Exterior Cap + 7/16" Air Space + 7/16" Laminated consisting of (1) Lite of 3/16" ANN Glass and (1) Lite of 3/16" HS Glass with .090" PVB Interlayer	2	7
4	1-1/16" Laminated I.G.: 1/4" T Exterior Cap + 3/8" Air Space + 7/16" Laminated consisting of (1) Lite of 3/16" ANN Glass and (1) Lite of 3/16" HS Glass with .090" PVB Interlayer	2	7
5	7/16" Laminated: (1) Lite of 3/16" ANN Glass and (1) Lite of 3/16" HS Glass with .090" SG Interlayer	1	7
6	9/16" Laminated: (1) Lite of 1/4" ANN Glass and (1) Lite of 1/4" HS Glass with .090" SG Interlayer	1	7
7	7/16" Laminated: (2) Lites of 3/16" HS Glass with .090" SG Interlayer	3	8
8	9/16" Laminated: (2) Lites of 1/4" HS Glass with .090" SG Interlayer	3	8
9	1-1/16" Laminated I.G.: 3/16" T Exterior Cap + 7/16" Air Space + 7/16" Laminated consisting of (1) Lite of 3/16" ANN Glass and (1) Lite of 3/16" HS Glass with .090" SG Interlayer	1	7
10	1-1/16" Laminated I.G.: 1/4" T Exterior Cap + 3/8" Air Space + 7/16" Laminated consisting of (1) Lite of 3/16" ANN Glass and (1) Lite of 3/16" HS Glass with .090" SG Interlayer	1	7
11	1-1/16" Laminated I.G.: 3/16" T Exterior Cap + 7/16" Air Space + 7/16" Laminated consisting of (2) Lites of 3/16" HS Glass with .090" SG Interlayer	3	8
12	1-1/16" Laminated I.G.: 1/4" T Exterior Cap + 3/8" Air Space + 7/16" Laminated consisting of (2) Lites of 3/16" HS Glass with .090" SG Interlayer	3	8

ANCHOR NOTES

- 1) FOR CONCRETE/CMU SUBSTRATE APPLICATIONS IN MIAMI-DADE COUNTY, USE ONLY MIAMI-DADE COUNTY APPROVED ELCO ANCHORS. SEE TABLE A ON THIS SHEET FOR EMBEDMENT, EDGE DISTANCE AND SUBSTRATE REQUIREMENTS.
2) FOR OTHER SUBSTRATE APPLICATIONS SEE TABLE A ON THIS SHEET.
3) WOOD BUCKS DEPICTED AS 1X ARE LESS THAN 1-1/2" THICK. PROPERLY SECURED, 1X WOOD BUCKS ARE OPTIONAL IF UNIT IS INSTALLED DIRECTLY TO SOLID CONCRETE OR CMU. WOOD BUCKS DEPICTED AS 2X ARE 1-1/2" THICK OR GREATER. 1X AND 2X BUCKS (WHEN USED) SHALL BE DESIGNED TO PROPERLY TRANSFER LOADS TO THE STRUCTURE. BUCK DESIGN AND INSTALLATION IS THE RESPONSIBILITY OF THE ENGINEER OR ARCHITECT OF RECORD & TO BE REVIEWED BY THE BUILDING OFFICIAL.
4) METAL SUBSTRATE TO MEET MIN. STRENGTH AND THICKNESS REQUIREMENTS PER CURRENT FLORIDA BUILDING CODE AND TO BE REVIEWED BY THE AUTHORITY HAVING JURISDICTION.
5) IF SILL IS TIGHT TO SUBSTRATE, GROUT OR OTHER MATERIAL IS NOT REQUIRED. IF USED, NON-SHRINK, NON-METALLIC GROUT, MAX. 1/4" THICK & 3400 PSI MIN., (DONE BY OTHERS) MUST FULLY SUPPORT THE ENTIRE LENGTH OF THE SILL THAT IS NOT TIGHT TO THE SUBSTRATE, AND TRANSFER SHEAR LOAD TO SUBSTRATE. IF SUBSTRATE IS WOOD, 30# FELT PAPER OR MASTIC IS REQUIRED BETWEEN THE GROUT AND WOOD SUBSTRATE, OR AS APPROVED BY THE AUTHORITY HAVING JURISDICTION.

TABLE A:

Group	Anchor	Substrate	Frame Member	Min. Edge Distance	Min. Embedment
A	1/4" Elco Ultracon	Concrete (min. 2.85 ksi)	Head/Sill/Jamb/P-hook	2-1/2"	1-3/8"
		UngROUTED CMU, (ASTM C-90)	Jamb/P-hook	2-1/2"	1-1/4"
B	1/4" Elco 410 S.S. CreteFlex	Concrete (min. 3.35 ksi)	Head/Sill/Jamb/P-hook	1"	1-3/4"
		P.T. Southern Pine (SG=0.55)	Head/Sill/Jamb/P-hook	1"	1-3/8"
		UngROUTED CMU, (ASTM C-90)	Jamb/P-hook	1-3/4"	1-1/4"
C	1/4" Elco Ultracon	Concrete (min. 2.85 ksi)	Head/Sill/Jamb/P-hook	1"	1-3/8"
		UngROUTED CMU, (ASTM C-90)	Jamb	1"	1-1/4"
	#12, steel SMS (G5) or 410 S.S. SMS, (min. 11 threads/in)		P-hook	2-1/2"	1-1/4"
		P.T. Southern Pine (SG=0.55)	Head/Sill/Jamb/P-hook	9/16"	1-3/8"
		Aluminum, 6063-T5*	Head/Sill/Jamb	3/8"	0.0713"
			P-hook	3/8"	0.125"
		Steel, A36*	Head/Sill/Jamb/P-hook	3/8"	0.060"
D	1/4" Elco 18-8 S.S. Aggre-Gator	Steel Stud, A653 Gr. 33*	Head/Sill/Jamb/P-hook	3/8"	0.056"
		Concrete (min. 2.22 ksi)	Head/Sill/Jamb/P-hook	1-1/2"	1-3/8"
		UngROUTED CMU, (ASTM C-90)	Jamb/P-hook	2"	1-1/4"
		Grouted CMU (ASTM C-90, min. 2 ksi grout)	Jamb/P-hook	2"	2"
		P.T. Southern Pine (SG=0.55)	Head/Sill/Jamb/P-hook	1"	1-3/8"

* MIN. OF 3 THREADS BEYOND THE METAL SUBSTRATE. METAL SUBSTRATE TO MEET MIN. STRENGTH AND THICKNESS REQUIREMENTS PER CURRENT FLORIDA BUILDING CODE AND TO BE REVIEWED BY THE AUTHORITY HAVING JURISDICTION.

FOR STEEL STUDS, MIN. FU=45 KSI & MIN. FY=33 KSI.


"UNGROUTED CMU" VALUES MAY BE USED FOR GROUTED CMU APPLICATIONS.

IMPACT RATING
RATED FOR LARGE & SMALL MISSILE IMPACT RESISTANCE

DESIGN PRESSURE RATING
SEE TABLES 1-3 & C1-C2 ON SHEETS 7 & 8


GENERAL NOTES..... 1
EXAMPLE CONFIGS..... 2
INSTALL DETAILS..... 3-6
DP/ANCHOR TABLES..... 7-8
EXAMPLES..... 9-10
GLAZING DETAILS..... 11
ANCHOR LOCATIONS..... 12-15
PANEL TYPES..... 16
EXTRUSIONS..... 17
PARTS LIST..... 18

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 16-0629.10
Expiration Date: 01/02/2017
Anthony Lynn Miller
Professional Engineer




STANDARDS USED:

- 2014 FLORIDA BUILDING CODE (FBC), 5TH EDITION
- ASTM E1300-09
- ANSI/AF&PA NDS-2012 FOR WOOD CONSTRUCTION
- ALUMINUM DESIGN MANUAL, ADM-2010
- AISI-S100-07/S2-2010



1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
(941)-480-1600

Series	SGD-780	Scale	NTS	Sheet	1 OF 18	DWG No.	MD-780.0	Rev. No.	A
Title	ALUMINUM SLIDING GLASS DOOR NOA (LM)								Date
Desc.	GENERAL NOTES							Drawn By	J ROSOWSKI
Rev A	ADDED SPACERS TO SHEET 11. - JR							Rev A Date	05/15/16



CONFIGURATIONS NOTES:

1) ALL CONFIGURATIONS SHOWN ARE ALSO AVAILABLE AS POCKET CONFIGURATIONS AT EITHER OR BOTH JAMB LOCATIONS. EXAMPLE: 4-PANEL XXXX IN POCKET (p) CONFIGURATION CAN BE pXXXXp, pXXXX OR XXXXp. OXXX IN POCKET CONFIGURATION CAN BE OXXXp.

2) 90° & 135° CORNER CONFIGURATIONS ARE A COMBINATION OF ANY 2 STRAIGHT CONFIGURATIONS.

3) POCKET WALL OR CAVITY IS NOT PART OF THIS APPROVAL AND IS TO BE DESIGNED BY OTHERS AND REVIEWED BY THE AUTHORITY HAVING JURISDICTION.

4) FOR NOM. PANEL WIDTH, SEE TABLES 1-3.

5) MAX. ALLOWABLE FRAME SQUARE FOOTAGE = 462.11 FT²

DETAIL LETTER
X#
SHEET NUMBER

"X" = OPERABLE PANEL
"O" = INOPERABLE PANEL
"p" = POCKET


DLO WIDTH = NOM. PANEL WIDTH - 7.875"
DLO HEIGHT (STD. BOT. RAIL, #22) = DOOR UNIT HEIGHT - 13.47"
DLO HEIGHT (TALL BOT. RAIL, #23) = DOOR UNIT HEIGHT - 17.29"
PANEL HEIGHT = DOOR UNIT HEIGHT - 2.25"



Series	SGD-780	Scale	NTS	Sheet	2 OF 18	DWG No.	MD-780.0	Rev. No.	A
Title		ALUMINUM SLIDING GLASS DOOR NOA (LM)		Date		10/05/15			
Desc.		CONFIGURATIONS		Drawn By		J ROSOWSKI			
Rev A		Rev A		Date					
Rev B		Rev B		Date					

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No 16-0629-10
Expiration Date 08/02/17
A. Lynn Miller, P.E.
Product Control





- NOTES**
- 1) DETAILS APPLY TO 2, 3 AND 4 TRACK CONFIGURATIONS.
 - 2) REFER TO ANCHOR NOTES, SHEET 1.
 - 3) SEE SHEET 12 FOR ANCHOR LOCATION & SPACING, FOR ANCHOR QUANTITIES, SEE TABLES 1-3.
 - 4) ALL REINFORCEMENTS ARE APPROXIMATELY THE FULL LENGTH OF THE EXTRUSION. REFER TO TEST REPORTS FOR EXACT DIMENSIONS.
 - 5) FOR DAYLIGHT OPENING (DLO) FORMULAS, SEE SHEET 2.

PGT

CERT. OF AUTH. #29296


1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
(941)-480-1600

Series	Rev	A	Desc	Title		Date	
				ALUMINUM SLIDING GLASS DOOR NOA (LM)		10/05/15	
Series	Rev	B	A	Date	By	J ROSOWSKI	
						INSTALLATION, HORIZONTAL X-SECT.	
SGD-780						Scale	NTS
						Sheet	3 OF 18
						DWG No.	MD-780.0
						Rev. No.	A


PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No 16-0629.10
Expiration Date 02/02/17
A. Lynn Miller
Miami Door Product Control

6/8/16


A. LYNN MILLER, P.E.
P.E.# 58705




DETAIL G1
135°
INSIDE CORNER




DETAIL G2
135°
OUTSIDE CORNER



DETAIL H1
90°
INSIDE CORNER



DETAIL H2
90°
OUTSIDE CORNER



NOTES





- 1) DETAILS APPLY TO 2, 3 AND 4 TRACK CONFIGURATIONS.
- 2) SEE SHEETS 14-15 FOR ANCHOR LOCATION & SPACING, FOR ANCHOR QUANTITIES, SEE TABLES 1-3.
- 3) CORNER ASTRAGAL MAY BE EITHER TO THE INTERIOR OR EXTERIOR, DEPENDING ON CONFIGURATION.

PGT
CERT. OF AUTH. #29296
1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
(941)-480-1600

Title		ALUMINUM SLIDING GLASS DOOR NOA (LM)		Date	10/05/15
Desc.		CORNER ASTRAGAL HORIZ. X-SECT.		Drawn By	J ROSOWSKI
Rev A	Rev A			Date	
Rev B	Rev B			Date	
Series	SGD-780	Scale	NTS	Sheet	5 OF 18
DWG No.	MD-780.0	Rev. No.	A		


PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 16-0629-10
Expiration Date 02/02/17
A. Lynn Miller
Member Product Council

ALUMINUM SLIDING GLASS DOOR NOA (LM)
No. 58705
A. Lynn Miller
6/8/16
A. LYNN MILLER, P.E.
P.E.# 58705



NOTES

- 1) DETAILS APPLY TO 2, 3 AND 4 TRACK CONFIGURATIONS.
- 2) REFER TO ANCHOR NOTES, SHEET 1.
- 3) SEE SHEET 15 FOR ANCHOR LOCATION & SPACING.
- 4) #10 X 3/4" SMS @ MAX. 5-1/2" FROM ENDS & 12" MAX. O.C.
- 5) INTERIOR OR EXTERIOR POCKETS APPLICABLE FOR ALL INSTALLATION METHODS.
- 6) POCKET WALL OR CAVITY IS NOT PART OF THIS APPROVAL AND IS TO BE DESIGNED BY OTHERS AND REVIEWED BY THE AUTHORITY HAVING JURISDICTION.



ALUMINUM SLIDING GLASS DOOR NOA (LM)		Date	10/05/15
P-HOOK EXAMPLES, HORIZ. X-SECT.		Drawn By	J ROSOWSKI
Series	Rev A	Rev A Date	
		Rev B Date	
SGD-780	Scale	NTS	Sheet 6 OF 18
DWG No.	MD-780.0	Rev. No.	A

PRODUCT REVISED
As complying with the Florida
Building Code
Acceptance No 16-0629.10
Expiration Date 08/02/17
A. Lynn Miller, P.E.
Product Control




TABLE 1:

Design Pressure (DP) and Anchor Quantities Required, (for all approved configurations on Sheet 2)																							
For corner astragal anchorage on 90° & 135° corner units, see sheets 14 & 15																							
Table applies to Glass Types 5, 6, 9 & 10 containing ANN-HS SG Laminated Glazing. Reinforcement (part #29) is not required in the Exterior Interlock.				Door Unit Height																			
				80"				84"				96"				108"				120"			
				77-3/4" Panel Height**				81-3/4" Panel Height**				93-3/4" Panel Height**				105-3/4" Panel Height**				117-3/4" Panel Height**			
				Anchor Group				Anchor Group				Anchor Group				Anchor Group				Anchor Group			
				A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D
Nominal Panel Width	36"	28-1/8" DLO Width	Design Pressure	+80 / -80 psf				+80 / -80 psf				+80 / -80 psf				+60 / -70 psf				+60 / -70 psf			
			Head/Sill	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C6+1	C4+1	C4+1
			Jamb	6	6	6	6	8	8	8	8	8	8	8	8	8	8	8	8	10	10	10	10
			P-hook	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	5+5	5+5	5+5	5+5	5+5	5+5	5+5	5+5
	42"	34-1/8" DLO Width	Design Pressure	+80 / -80 psf				+80 / -80 psf				+80 / -80 psf				+60 / -70 psf				+60 / -70 psf			
			Head/Sill	C4+1	C4+2	C4+2	C4+1	C4+1	C4+2	C4+2	C4+1	C4+1	C4+2	C6+2	C4+1	C4+1	C6+1	C6+2	C4+1	C4+1	C6+1	C6+2	C4+1
			Jamb	6	6	6	8	8	8	8	8	8	8	8	10	8	8	8	10	10	10	10	10
			P-hook	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	5+5	5+5	5+5	5+5	5+5	5+5	5+5	5+5
	48"	40-1/8" DLO Width	Design Pressure	+80 / -80 psf				+80 / -80 psf				+80 / -80 psf				+60 / -70 psf				+60 / -70 psf			
			Head/Sill	C4+1	C4+2	C4+2	C4+2	C4+1	C4+2	C4+2	C4+2	C4+1	C6+2	C6+2	C4+2	C4+1	C6+2	C6+2	C4+2	C4+1	C6+2	C6+2	C6+2
			Jamb	6	6	6	8	8	8	8	8	8	8	8	10	8	8	8	10	10	10	10	12
			P-hook	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	5+5	5+5	5+5	5+5	5+5	5+5	5+5	5+5
	54"	46-1/8" DLO Width	Design Pressure	+80 / -80 psf				+80 / -80 psf				+80 / -80 psf				Not available in these sizes							
			Head/Sill	C4+2	C4+2	C4+2	C4+2	C4+2	C4+2	C6+2	C4+2	C4+2	C6+2	C6+2	C4+2								
			Jamb	6	6	6	8	8	8	8	8	8	8	8	10								
			P-hook	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4								
	60"	52-1/8" DLO Width	Design Pressure	+80 / -80 psf				+80 / -80 psf				+76.2 / -76.2 psf *				Not available in these sizes							
			Head/Sill	C4+2	C4+3	C4+3	C4+2	C4+2	C6+3	C6+3	C4+2	C4+2	C6+3	C6+3	C6+2								
			Jamb	6	6	6	8	8	8	8	10	8	8	8	12								
			P-hook	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4								

*+/- 80.0 PSF FOR GLASS TYPES 6, 9 & 10. **SEE FORMULAS BELOW

ANCHORAGE TYPE PER SUBSTRATE REQUIRED TO ACHIEVE THE DESIGN PRESSURE, USING THE ANCHOR QUANTITIES LISTED BELOW. SEE TABLE A, SHEET 1 FOR COMPLETE ANCHOR LIMITATIONS.

THE MAXIMUM DP AT THESE ANCHOR QUANTITIES. ADDITIONALLY, THE MAXIMUM POSITIVE DP DUE TO THE SILL HEIGHT MUST ALSO BE CONSIDERED, SEE TABLE C1, THIS SHEET.

TOTAL # OF ANCHORS CLUSTERED THROUGH THE HEAD & SILL AT EACH PANEL MEETING POINT. (EX: FOR C4+1, 4 ANCHORS REQUIRED AT PANEL MEETING POINT AND 1 ANCHOR REQUIRED AT MIDSPAN OF PANEL).

TOTAL # OF ANCHORS THROUGH THE JAMB.

THE # OF ANCHORS THROUGH THE P-HOOK INSTALLED FROM THE INTERIOR + THE # OF ANCHORS INSTALLED FROM THE EXTERIOR.

USED IN EXAMPLE 2, SHEET 10

TABLE NOTES:

- 1) IF WATER INFILTRATION RESISTANCE IS REQUIRED, THE LESSER VALUES OF EITHER TABLE 1 OR 2 AND TABLE C1 DETERMINES THE WATER LIMITED (+) DP.
- 2) THE 1-5/8" SILL RISER, #12, MAY ONLY BE USED WHERE WATER INFILTRATION RESISTANCE IS NOT REQUIRED OR OVERHANG IS PER FIG 1. IF SO, +DP'S SHOWN IN TABLES 1 OR 2 MAY BE USED.
- 3) SEE SILL RISER TYPES ON SHEET 4.
- 4) DETAILS APPLY TO 2, 3 AND 4 TRACK CONFIGURATIONS.
- 5) REFER TO ANCHOR NOTES, SHEET 1.
- 6) SEE SHEETS 12-15 FOR ANCHOR LOCATION & SPACING

TABLE 2:

Design Pressure (DP) and Anchor Quantities Required, (for all approved configurations on Sheet 2)															
For corner astragal anchorage on 90° & 135° corner units, see sheets 14 & 15															
Table applies to Glass Types 1 - 4, containing ANN-HS PVB Laminated Glazing. Reinforcement (part #29) is not required in the Exterior Interlock.				Door Unit Height											
				80"				96"							
				77-3/4" Panel Height**				93-3/4" Panel Height**							
				Anchor Group				Anchor Group							
				A	B	C	D	A	B	C	D				
Nominal Panel Width	36"	28-1/8" DLO Width	Design Pressure	+65 / -65 psf				+65 / -65 psf							
			Head/Sill	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1				
			Jamb	6	6	6	6	8	8	8	8				
			P-hook	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4				
	42"	34-1/8" DLO Width	Design Pressure	+65 / -65 psf				+65 / -65 psf							
			Head/Sill	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1				
			Jamb	6	6	6	6	8	8	8	8				
			P-hook	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4				
	48"	40-1/8" DLO Width	Design Pressure	+65 / -65 psf				+65 / -65 psf							
			Head/Sill	C4+1	C4+2	C4+2	C4+2	C4+1	C4+2	C4+2	C4+2				
			Jamb	6	6	6	6	8	8	8	8				
			P-hook	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4				

**SEE FORMULAS BELOW

DLO WIDTH = NOM. PANEL WIDTH - 7.875"
DLO HEIGHT (STD. BOT. RAIL, #22) = DOOR UNIT HEIGHT - 13.47"
DLO HEIGHT (TALL BOT. RAIL, #23) = DOOR UNIT HEIGHT - 17.29"
PANEL HEIGHT = DOOR UNIT HEIGHT - 2.25"

TABLE C1:


Water-Limited (+) Design Pressure		
Sill Riser	Total Sill Height	Max. (+) DP Allowed
12	1-5/8"	See Note 2
13	2-3/4"	+50.0 psf
14	3-1/2"	+73.3 psf
15	4-1/2"	+80.0 psf
16	5-1/4"	+80.0 psf

FIG 1:

OH LENGTH

OH HEIGHT

DOOR ASSEMBLIES INSTALLED WHERE THE OVERHANG (OH) LENGTH IS EQUAL TO OR GREATER THAN THE OVERHANG HEIGHT IS EXEMPTED FROM WATER INFILTRATION RESISTANCE.



CERT. OF AUTH. #29296

1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
(941)-480-1600

Series	ALUMINUM SLIDING GLASS DOOR NOA (LM)										Date	10/05/15
	DP & ANCHOR QUANTITY TABLE										Drawn By	J ROSOWSKI
											Rev A Date	
											Rev B Date	
SGD-780		Scale	NTS	Sheet	7 OF 18	DWG No.	MD-780.0	Rev. No.	A			

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No 16-0629-10
Expiration Date 03/02/17
A. Lynn Miller, P.E.
Miami Door Product Control




TABLE 3:


Design Pressure (DP) and Anchor Quantities Required, (for all approved configurations on Sheet 2)																															
For corner astragal anchorage on 90° & 135° corner units, see sheets 14 & 15																															
Table applies to Glass Types 7, 8, 11 & 12 containing HS-HS SG laminated glazing. Reinforcement (part #29) is required in the Exterior Interlock.			Door Unit Height																												
			80"				84"				96"				108"				120"				132"				144"				
			77-3/4" Panel Height**				81-3/4" Panel Height**				93-3/4" Panel Height**				105-3/4" Panel Height**				117-3/4" Panel Height**				129-3/4" Panel Height**				141-3/4" Panel Height**				
			Anchor Group				Anchor Group				Anchor Group				Anchor Group				Anchor Group				Anchor Group				Anchor Group				
			A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	A	B	C	D	
30"	22-1/8" DLO Width	Design Pressure	+105 / -115 psf				+105 / -115 psf				+105 / -115 psf				+105 / -115 psf				+105 / -115 psf				+104 / -104 psf				+92.7 / -94 psf				
		Head/Sill	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C4+1	C6+1	C6+1	C4+1	C4+1	C6+1	C6+1	C6+1	C6+1	C4+1	C6+1	C6+1	C6+1	C6+1	C6+1	C6+1	C6+1	C6+1	C6+1	C6+1	C6+1
		Jamb	6	6	6	8	8	8	8	8	8	8	8	10	8	8	8	12	10	10	10	12	10	10	10	12	12	12	12	12	
		P-hook	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	5+5	5+5	5+5	5+5	5+5	5+5	5+5	5+5	5+5	5+5	6+6	6+6	6+6	6+6	6+6	6+6	6+6
36"	28-1/8" DLO Width	Design Pressure	+105 / -115 psf				+105 / -115 psf				+105 / -115 psf				+105 / -115 psf				+105 / -115 psf				+101.6 / -111.2 psf				+77.9 / -85.3 psf				
		Head/Sill	C4+1	C6+2	C6+2	C4+1	C4+1	C6+2	C6+2	C4+1	C4+1	C6+2	C6+2	C6+1	C4+1	C6+2	C8+2	C6+1	C6+1	C8+2	C8+2	C6+1	C6+1	C8+2	C8+2	C8+1	C6+1	C8+1	C8+1	C6+1	
		Jamb	6	6	8	10	8	8	8	10	8	8	10	12	8	8	10	14	10	10	12	14	10	10	12	16	12	12	12	14	
		P-hook	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	5+5	5+5	5+5	5+5	5+5	5+5	5+5	5+5	5+5	5+5	6+6	6+6	6+6	6+6	6+6	6+6	6+6
42"	34-1/8" DLO Width	Design Pressure	+105 / -115 psf				+105 / -115 psf				+105 / -115 psf				+105 / -115 psf				+105 / -115 psf				+88 / -96.4 psf				+67.3 / -73.8 psf				
		Head/Sill	C4+2	C6+2	C6+2	C4+2	C4+2	C6+2	C6+2	C6+2	C4+2	C6+2	C6+2	C6+2	C6+2	C8+2	C8+2	C6+2	C6+2	C8+2	C8+2	C8+2	C6+1	C8+2	C8+2	C8+2	C6+1	C6+2	C8+2	C6+1	
		Jamb	6	6	8	10	8	8	8	10	8	8	10	12	8	8	12	14	10	10	12	16	10	10	12	16	12	12	12	14	
		P-hook	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	5+5	5+5	5+5	5+5	5+5	5+5	5+5	5+5	5+5	5+5	6+6	6+6	6+6	6+6	6+6	6+6	6+6
48"	40-1/8" DLO Width	Design Pressure	+105 / -115 psf				+105 / -115 psf				+105 / -115 psf				+105 / -115 psf				+105 / -115 psf				+78 / -85.4 psf				+59.6 / -65.2 psf				
		Head/Sill	C4+2	C6+3	C6+3	C6+2	C4+2	C6+3	C6+3	C6+2	C6+2	C8+3	C8+3	C6+2	C6+2	C8+3	C8+3	C8+2	C6+2	C10+3	C10+3	C8+2	C6+2	C8+2	C8+2	C6+2	C6+1	C6+2	C8+2	C6+2	
		Jamb	6	6	8	12	8	8	10	12	8	8	10	14	8	8	12	16	10	10	14	18	10	10	12	16	12	12	12	14	
		P-hook	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	5+5	5+5	5+5	5+5	5+5	5+5	5+5	5+5	5+5	6+6	6+6	6+6	6+6	6+6	6+6	6+6	6+6	6+6
54"	46-1/8" DLO Width	Design Pressure	+105 / -115 psf				+105 / -115 psf				+105 / -115 psf				+105 / -115 psf				+94.8 / -103.8 psf				Not available in these sizes								
		Head/Sill	C4+2	C6+3	C6+3	C6+3	C4+2	C6+3	C6+3	C6+3	C6+2	C8+3	C8+3	C6+3	C6+2	C8+3	C10+3	C8+3	C6+2	C10+3	C10+3	C8+3									
		Jamb	6	6	10	12	8	8	10	12	8	8	12	14	8	8	14	18	10	10	14	18									
		P-hook	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	5+5	5+5	5+5	5+5	6+6	5+5	5+5	5+5	6+6									
60"	52-1/8" DLO Width	Design Pressure	+105 / -115 psf				+105 / -115 psf				+105 / -115 psf				+103.4 / -113.2 psf				+86.7 / -95 psf												
		Head/Sill	C4+3	C6+4	C6+4	C6+3	C4+3	C6+4	C8+4	C6+3	C6+3	C8+4	C8+4	C8+3	C6+3	C10+4	C10+4	C8+3	C6+2	C10+3	C10+3	C8+3									
		Jamb	6	6	10	12	8	8	10	14	8	8	12	16	8	8	14	18	10	10	14	18									
		P-hook	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	4+4	5+5	5+5	5+5	5+5	6+6	5+5	5+5	5+5	6+6									

**SEE FORMULAS BELOW

TABLE C2:

Water-Limited (+) Design Pressure		
Sill Riser	Total Sill Height	Max. (+) DP Allowed
12	1-5/8"	See Note 2
13	2-3/4"	+50.0 psf
14	3-1/2"	+73.3 psf
15	4-1/2"	+100.0 psf
16	5-1/4"	+105.0 psf

FIG 1:



DOOR ASSEMBLIES INSTALLED WHERE THE OVERHANG (OH) LENGTH IS EQUAL TO OR GREATER THAN THE OVERHANG HEIGHT IS EXEMPTED FROM WATER INFILTRATION RESISTANCE.

DLO WIDTH = NOM. PANEL WIDTH - 7.875"
DLO HEIGHT (STD. BOT. RAIL, #22) = DOOR UNIT HEIGHT - 13.47"
DLO HEIGHT (TALL BOT. RAIL, #23) = DOOR UNIT HEIGHT - 17.29"
PANEL HEIGHT = DOOR UNIT HEIGHT - 2.25"

TABLE NOTES:

- 1) IF WATER INFILTRATION RESISTANCE IS REQUIRED, THE LESSER VALUE OF TABLE 3 AND TABLE C2 DETERMINES THE WATER LIMITED (+) DP.
- 2) THE 1-5/8" SILL RISER, #12, MAY ONLY BE USED WHERE WATER INFILTRATION RESISTANCE IS NOT REQUIRED OR OVERHANG IS PER FIG 1. IF SO, +DP'S SHOWN IN TABLE 3 MAY BE USED.
- 3) SEE SILL RISER TYPES ON SHEET 4.
- 4) DETAILS APPLY TO 2, 3 AND 4 TRACK CONFIGURATIONS.
- 5) REFER TO ANCHOR NOTES, SHEET 1.
- 6) SEE SHEETS 12-15 FOR ANCHOR LOCATION & SPACING



Series	SGD-780	Scale	NTS	Sheet	8 OF 18	DWG No.	MD-780.0	Rev. No.	A
Rev A	Date	Rev B	Date	Rev C	Date	Rev D	Date	Rev E	Date
ALUMINUM SLIDING GLASS DOOR NOA (LM)		DP & ANCHOR QUANTITY TABLE		J ROSOWSKI		10/05/15			

ANCHORAGE TYPE PER SUBSTRATE REQUIRED TO ACHIEVE THE DESIGN PRESSURE, USING THE ANCHOR QUANTITIES LISTED BELOW. SEE TABLE A, SHEET 1 FOR COMPLETE ANCHOR LIMITATIONS.

THE MAXIMUM DP AT THESE ANCHOR QUANTITIES. ADDITIONALLY, THE MAXIMUM POSITIVE DP DUE TO THE SILL HEIGHT MUST ALSO BE CONSIDERED, SEE TABLE C2, THIS SHEET.

TOTAL # OF ANCHORS CLUSTERED THROUGH THE HEAD & SILL AT EACH PANEL MEETING POINT. (EX: FOR C6+1, 6 ANCHORS REQUIRED AT PANEL MEETING POINT AND 1 ANCHOR REQUIRED AT MIDSPAN OF PANEL).


TOTAL # OF ANCHORS THROUGH THE JAMB.

THE # OF ANCHORS THROUGH THE P-HOOK INSTALLED FROM THE INTERIOR + THE # OF ANCHORS INSTALLED FROM THE EXTERIOR.

USED IN EXAMPLE 1, SHEET 9

PRODUCT REVISED as complying with the Florida Building Code
Acceptance No. 16-0629.10
Expiration Date 08/02/17
A. LYNN MILLER, P.E.
P.E.# 58705

3-PANEL, 3 TRACK, STRAIGHT CONFIGURATION - PXXX,
INTERIOR MOUNT POCKET,
48" X 84" NOM. PANELS, LAMINATED, IG GLAZING,
ANCHOR GROUP 3 IN WOOD SUBSTRATE,
PROJECT DESIGN PRESSURE REQUIRED: +98.2/-108.6 PSF



1) KNOWING THE PRODUCT'S REQUIREMENTS, SCAN THROUGH TABLES 1-3 FOR A DESIGN PRESSURE THAT MEETS OR EXCEEDS THE REQUIREMENT OF +98.2/-108.6 AT A NOM. PANEL SIZE OF 48" X 84". FROM TABLE 3, SHEET 8, THE DESIGN PRESSURE IS +105/-115 WHICH EXCEEDS THE PROJECT DESIGN PRESSURE REQUIREMENTS.

Head/Sill	C6+3
Jamb	10
P-hook	4+4

2) ANCHOR LOCATION DETAILS, (AS SHOWN ON THIS SHEET) CAN BE FOUND ON:
HEAD/SILL: SHEET 13 FOR THE "C6" CLUSTER ANCHORS AT INTERLOCK, SHEET 12 FOR THE INTERMEDIATE "+3 ANCHORS
 LOCATED AT THE CENTERLINE OF ALL 3 PANELS.
JAMB: 5 PAIRS OF ANCHORS = 10 TOTAL ANCHORS; REFER TO SHEET 12 FOR GENERAL LAYOUT.
P-HOOK: 4 ANCHORS PERPENDICULAR TO GLASS AND 4 ANCHORS PARALLEL TO GLASS; REFER TO SHEET 15 FOR GENERAL
 LAYOUT.

3) INSTALLATION DETAILS INTO WOOD CAN BE FOUND ON:
HEAD/SILL & JAMB: SHEETS 3 & 4
P-HOOK: SHEET 6


FOR PRODUCT REFERENCES, ALSO SEE:

- A) SHEET 2 FOR ALLOWABLE CONFIGURATIONS AND EXACT LOCATIONS OF CROSS-SECTION DRAWINGS.
- B) SHEET 11 FOR SPECIFIC GLAZING TYPES.
- C) SHEET 16 FOR ALLOWABLE PANEL TYPES AND CALL NAMES.
- D) SHEETS 4 & 17 FOR EXTRUSION CROSS-SECTION DRAWINGS.
- E) SHEET 18 FOR A BILL OF MATERIALS.




Series	Rev B	Rev A	Desc.	Title
SGD-780			ALUMINUM SLIDING GLASS DOOR NOA (LM)	Date 10/05/1
			STRAIGHT DOOR EXAMPLE	Drawn By J ROSOWSK
				Rev A Date
				Rev B Date

PRODUCT REVISED
as complying with the Florida
building Code
Acceptance No 16-0629-11
Expiration Date 02/02/17
S. Shueh-Chen
Major Design Product Control



EXAMPLE 2:
5-PANEL, 2 TRACK,
90° OUTSIDE CORNER - PXX/XXO,
EXTERIOR MOUNT POCKET,
60" X 84" NOM. PANELS, LAMINATED GLAZING
ANCHOR GROUP 1 IN CONCRETE SUBSTRATE
PROJECT DESIGN PRESSURE REQUIRED: +68.4/-77.1 PSF



USER INSTRUCTIONS:

1) KNOWING THE PRODUCT REQUIREMENTS, SCAN THROUGH TABLES 1-3 FOR A DESIGN PRESSURE THAT MEETS OR EXCEEDS THE REQUIREMENT OF +68.4/-77.1 AT A NOM. PANEL SIZE OF 60" X 84". FROM TABLE 1, SHEET 7, THE DESIGN PRESSURE IS +80/-80 WHICH EXCEEDS THE PROJECT DESIGN PRESSURE REQUIREMENTS.

FOR CONCRETE INSTALLATION
USING ANY ANCHOR IN GROUP
A (SEE TABLE A), TABLE 1 SHOWS
ANCHOR REQUIREMENTS OF:


Head/Sill	C4+2
Jamb	8
P-hook	4+4

2) ANCHOR LOCATION DETAILS, (AS SHOWN ON THIS SHEET) CAN BE FOUND ON:
HEAD/SILL: SHEET 13 FOR THE "C4" CLUSTER ANCHORS LOCATED AT THE ASTRAGAL AND INTERLOCKS,
SHEET 12 FOR THE INTERMEDIATE "+2" ANCHORS.
HEAD/SILL @ CORNER: SHEET 14 FOR THE "C4" CLUSTER ANCHORS @ THE 90° CORNER.
JAMB: 4 PAIRS OF ANCHORS = 8 TOTAL ANCHORS; REFER TO SHEET 12 FOR GENERAL LAYOUT.
P-HOOK: 4 ANCHORS PERPENDICULAR TO GLASS AND 4 ANCHORS PARALLEL TO GLASS; REFER TO SHEET 15 FOR GENERAL LAYOUT.

3) INSTALLATION DETAILS INTO CONCRETE CAN BE FOUND ON:
HEAD/SILL & JAMB: SHEETS 3 & 4
P-HOOK: SHEET 6

FOR PRODUCT REFERENCES, ALSO SEE:
A) SHEET 2 FOR ALLOWABLE CONFIGURATIONS AND EXACT LOCATIONS OF CROSS-SECTION DRAWINGS.
B) SHEET 11 FOR SPECIFIC GLAZING TYPE.
C) SHEET 16 FOR ALLOWABLE PANEL TYPES AND CALL NAMES.
D) SHEETS 4 & 17 FOR EXTRUSION CROSS-SECTION DRAWINGS.
E) SHEET 18 FOR A BILL OF MATERIALS.

END PANEL ANCHOR EXCEPTION:




PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 16-0629.10
Expiration Date 08/02/17
By: [Signature]
Michael Decker Product Control


STATE OF FLORIDA
Professional Engineer
A. LYNN MILLER, P.E.
P.E.# 58705

PGT
CERT. OF AUTH. #29296
1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
(941)-480-1600


Title	ALUMINUM SLIDING GLASS DOOR NOA (LM)	Date	10/05/15
Desc.	CORNER DOOR EXAMPLE	Drawn By	J ROSOWSKI
Rev 1		Rev 1 Date	
Rev 2		Rev 2 Date	
Series	SGD-780	Scale	NTS
Sheet	10 OF 18	DWG No.	MD-780.0
Rev. No.	A		




GLASS TYPE 1 (WITH PVB)
GLASS TYPE 5 (WITH SG)




GLASS TYPE 2 (WITH PVB)
GLASS TYPE 6 (WITH SG)




GLASS TYPE 3 (WITH PVB)
GLASS TYPE 9 (WITH SG)




GLASS TYPE 4 (WITH PVB)
GLASS TYPE 10 (WITH SG)




GLASS TYPE 7




GLASS TYPE 8




GLASS TYPE 11




GLASS TYPE 12




72 KODISPACE
4SG TPS



73 SUPER
SPACER[®] NXT[™]



74 DURASEAL[®]
SPACER



75 XL EDGE[™]
SPACER

"ANN" = ANNEALED
"HS" = HEAT STRENGTHENED
"T" = TEMPERED
"PVB" = .090" BUTACITE[®] PVB
INTERLAYER BY KURARAY
AMERICA, INC.
"SG" = .090" SENTRYGLAS[®]
INTERLAYER BY KURARAY
AMERICA, INC.


Part #	Description	Material
72	Kommerling 4SG TPS Spacer System	See this Sheet for Materials
73	Quanex Super Spacer nXT with Hot Melt Butyl	
74	Quanex Duraseal Spacer	
75	Cardinal XL Edge Spacer	

REFERENCE TEST REPORTS: FTL-8717, 8968 & 8970




Title	ALUMINUM SLIDING GLASS DOOR NOA (LM)							Date	10/05/15
Desc.	GLAZING & SPACER DETAILS					Drawn By	J ROSOWSKI		
Rev A	ADDED SPACERS - JR							Rev A Date	05/15/16
Rev B								Rev B Date	
Series	SGD-780	Scale	NTS	Sheet	11 OF 18	DWG No.	MD-780.0	Rev. No.	A


PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 16-0629-10
Expiration Date 02/02/17
By: [Signature]
Mr. [Name] Product Control



JAMB ANCHOR LAYOUT FOR ALL DOORS:




FIGURES PERTAIN TO THE FOLLOWING JAMB ANCHOR LOCATIONS:




Head/Sill	C4+1
Jamb	8
P-hook	4+4

- NOTES:
- 1) ALL DIMENSIONS SHOWN ARE BASED ON MINIMUM ALLOWED, UNLESS OTHERWISE NOTED.
 - 2) FOR 3-TRACK JAMBS, ANCHORS MAY BE INSTALLED EITHER IN THE EXT. OR INT. TRACK.
 - 3) MIN. OF 8 ANCHORS IN JAMB (4 PAIRS).

HEAD/SILL "+" INTERMEDIATE ANCHORS LAYOUT FOR ALL DOORS:



FIGURES PERTAIN TO THE FOLLOWING INTERMEDIATE ANCHOR LOCATIONS:



Head/Sill	C4+1
Jamb	8
P-hook	4+4

- NOTES:
- 1) ALL DIMENSIONS SHOWN ARE BASED ON MINIMUM ALLOWED.
 - 2) SILL SHOWN, HEAD SIMILAR.




1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
(941)-480-1600

Series	SGD-780	Scale	NTS	Sheet	12 OF 18	DWG No.	MD-780.0	Rev. No.	A
Title	ALUMINUM SLIDING GLASS DOOR NOA (LM)				Date	10/05/15			
Desc.	ANCHOR LAYOUT				Drawn By	J ROSOWSKI			
Rev A					Rev A Date				
Rev B					Rev B Date				


PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 16-0629.10
Expiration Date 08/02/17
A. Lynn Miller, P.E.
Manager, Product Control

A. LYNN MILLER, P.E.
P.E.# 58705

HEAD/SILL CLUSTER ANCHORS LAYOUT FOR STRAIGHT DOORS:



- NOTES:
- 1) ALL DIMENSIONS SHOWN ARE BASED ON MINIMUM ALLOWED.
 - 2) SILL SHOWN, HEAD SIMILAR.
 - 3) IF A SPLICE IS NOT SHOWN AT A GIVEN CLUSTER QUANTITY, USE THE NEXT HIGHER CLUSTER QUANTITY.




CERT. OF AUTH. #29296

1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
(941)-480-1600


Title		ALUMINUM SLIDING GLASS DOOR NOA (LM)		Date	10/05/15
Desc.		ANCHOR LAYOUT		Drawn By	J ROSOWSKI
Rev A				Rev A Date	
Rev B				Rev B Date	
Series	SGD-780	Scale	NTS	Sheet	13 OF 18
DWG No.	MD-780.0	Rev. No.	A		

FIGURES PERTAIN TO THE FOLLOWING INTERLOCK/ASTRAGAL ANCHOR LOCATIONS:














Head/Sill	C4+1
Jamb	8
P-hook	4+4

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 16-0628-10
Expiration Date 02/02/17
A. Lynn Miller, P.E.
Miami Daily Product Control



HEAD/SILL 90° CORNER CLUSTER ANCHORS LAYOUT:



- NOTES:
- 1) ALL DIMENSIONS SHOWN ARE BASED ON MINIMUM ALLOWED.
 - 2) DETAILS DEPICT ANCHOR QUANTITY AND SPACING, AND WOULD BE SIMILAR FOR INSIDE AND OUTSIDE CORNER CONFIGURATIONS.
 - 3) SILL SHOWN, HEAD SIMILAR.

FIGURES PERTAIN TO THE FOLLOWING 90° CORNER ANCHOR LOCATIONS:

Head/Sill	C4+1
Jamb	8
P-hook	4+4


PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 16-0629.10
Expiration Date 08/02/17
A. Lynn Miller
Metal Door Product Control

A. LYNN MILLER, P.E.
P.E.# 58705

PGT
CERT. OF AUTH. #29296
1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
(941)-480-1600

Title	ALUMINUM SLIDING GLASS DOOR NOA (LM)							Date	10/05/15					
Desc.	ANCHOR LAYOUT						Drawn By	J ROSOWSKI						
Rev 1								Rev 1 Date						
Rev 2								Rev 2 Date						
Series	SGD-780		Scale	NTS		Sheet	14 OF 18		DWG No.	MD-780.0		Rev. No.	A	

P-HOOK ANCHORS LAYOUT FOR ALL DOORS:




NOTES:
1) SEE TABLES 1-3 FOR EXACT QUANTITY OF ANCHORS REQUIRED IN THE P-HOOK.

FIGURE PERTAINS TO THE FOLLOWING POCKET JAMB (P-HOOK) ANCHOR LOCATIONS:

POCKET	
POCKET	
Head/Sill	C4+1
Jamb	8
P-hook	5+5

HEAD/SILL 135° CORNER CLUSTER ANCHORS LAYOUT:



FIGURES PERTAIN TO THE FOLLOWING 135° CORNER ANCHOR LOCATIONS:

Head/Sill	C4+1
Jamb	8
P-hook	4+4

NOTES:
1) ALL DIMENSIONS SHOWN ARE BASED ON MINIMUM ALLOWED.
2) DETAILS DEPICT ANCHOR QUANTITY AND SPACING, AND WOULD BE SIMILAR FOR INSIDE AND OUTSIDE CORNER CONFIGURATIONS.
3) SILL SHOWN, HEAD SIMILAR.

PGT
CERT. OF AUTH. #29296
1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
(941)-480-1600


Series	SGD-780	Scale	NTS	Sheet	15 OF 18	DWG No.	MD-780.0	Rev. No.	A
Title	ALUMINUM SLIDING GLASS DOOR NOA (LM)								Date
Desc.	ANCHOR LAYOUT								10/05/15
Rev 1	By J ROSOWSKI								Date
Rev 2									Date

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No 16-0629.10
Expiration Date 08/02/17
A. Lynn Miller, P.E.
No. 58705


6/8/16

A. LYNN MILLER, P.E.
P.E.# 58705


PANEL TYPES	SINGLE INTERLOCK OUT	SINGLE INTERLOCK IN	DOUBLE INTERLOCK	FIXED STILE	LOCKSTILE W/ HANDLE	ASTRAGAL BOX IN	ASTRAGAL BOX IN W/ HANDLE	ASTRAGAL BOX OUT	ASTRAGAL BOX OUT W/ HANDLE	INSIDE 90° ASTRAGAL RECEIVER W/ HANDLE	OUTSIDE 90° ASTRAGAL RECEIVER	OUTSIDE 90° ASTRAGAL RECEIVER W/ HANDLE	INSIDE 90° CORNER LOCKSTILE W/ HANDLE	OUTSIDE 90° CORNER LOCKSTILE W/ HANDLE	OUTSIDE 135° ASTRAGAL RECEIVER	INSIDE 135° ASTRAGAL RECEIVER	OUTSIDE 135° ASTRAGAL RECEIVER W/ HANDLE	INSIDE 135° ASTRAGAL RECEIVER W/ HANDLE
SINGLE INTERLOCK OUT																		
	E	F		PP	K		L (BOX IN)		L (BOX OUT)	TA		TC	TR	TQ			TV	TW
SINGLE INTERLOCK IN		B		P	A		C (BOX IN)		C (BOX OUT)	SA		SC	IC	SQ			SV	SW
DOUBLE INTERLOCK			I	YR	GR													
FIXED STILE		RR	R	Y		S (BOX IN)		S (BOX OUT)		FD	FC				FV	FW		
LOCKSTILE W/ HANDLE		D	M	G		J (BOX IN)	W (BOX IN)	J (BOX OUT)	W (BOX OUT)									
ASTRAGAL BOX IN					T (BOX IN)				U (BOX IN)									
ASTRAGAL BOX IN W/ HANDLE			N (BOX IN)															
ASTRAGAL BOX OUT					T (BOX OUT)				U (BOX OUT)									
ASTRAGAL BOX OUT W/ HANDLE		LR (BOX OUT)		WR (BOX OUT)														
INS. 90° ASTRAGAL RECEIVER W/ HANDLE		AT	AS		DF													
OUTSIDE 90° ASTRAGAL RECEIVER					CF													
OUT. 90° ASTRAGAL RECEIVER W/ HANDLE		CT	CS															
INS. 90° CORNER LOCKSTILE W/ HANDLE		RT	CI															
OUT. 90° CORNER LOCKSTILE W/ HANDLE		QT	QS															
OUTSIDE 135° ASTRAGAL RECEIVER					VF													
INSIDE 135° ASTRAGAL RECEIVER					WF													
OUTSIDE 135° AST. RECEIVER W/ HANDLE		VT	VS															
INSIDE 135° AST. RECEIVER W/ HANDLE		WT	WS															



PANEL "E" SHOWN. SEE TABLE FOR OTHER PANEL TYPES AND APPLICABLE STILE/ASTRAGAL REQUIREMENTS.



PANEL CORNER DETAIL
SHOWN WITHOUT STILE COVER





FRAME CORNER DETAIL
3-TRACK FRAME SHOWN

PANEL NOTES:

- SEE DP/ANCHOR TABLES 1-3, SHEETS 7-8 FOR PANEL SIZES & DESIGN PRESSURE.
- PANEL TYPES NOT SHOWN ARE NOT REQUIRED FOR ANY CONFIGURATIONS AND ARE NOT AVAILABLE.
- MAXIMUM NOMINAL PANEL WIDTH FOR ALL PANEL CONFIGURATIONS IS 60".

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No 16-0629.10
Expiration Date 08/02/17
By [Signature]
Michael Decker Product Control






CERT. OF AUTH. #29296

1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
(941)-480-1600

Title		ALUMINUM SLIDING GLASS DOOR NOA (LM)		Date		10/05/15	
Desc.		PANEL TYPES		Drawn By		J ROSOWSKI	
Rev A				Rev A Date			
Rev B				Rev B Date			
Series	SGD-780	Scale	NTS	Sheet	16 OF 18	DWG No.	MD-780.0
						Rev. No.	A



NOTES: 1) SEE SHEET 4 FOR SILL RISERS. ALL DIMENSIONS IN INCHES.

PGT

CERT. OF AUTH. #29296

1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
(941)-480-1600

Title		ALUMINUM SLIDING GLASS DOOR NOA (LM)		Date	10/05/15
Desc.		EXTRUSIONS		Drawn By	J ROSOWSKI
Rev A	Rev B	Rev C	Rev D	Rev E	Rev F
SGD-780					
Scale	.25	Sheet	17 OF 18	DWG No.	MD-780.0
				Rev. No.	A

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 16-0629-10
Expiration Date 08/02/17
A. Lynn Miller, P.E.
Miller Design Products Control

A. Lynn Miller
6/8/16

A. LYNN MILLER, P.E.
P.E.# 58705

TABLE D:

#	Part #	Description	Material
1	8134	2-Track Jamb	6063 T6 Al
2	8135	2-Track Jamb with Screen Rail	6063 T6 Al
3	8133	3-Track Jamb	6063 T6 Al
4	8132	4-Track Jamb	6063 T6 Al
5	8118	2-Track Sill	6063 T6 Al
6	8116	3-Track Sill	6063 T6 Al
7	8120	4-Track Sill	6063 T6 Al
8	8127A	2-Track Head	6063 T6 Al
9	8128A	2-Track Head with Screen Rail	6063 T6 Al
10	8124	3-Track Head	6063 T6 Al
11	8121	4-Track Head	6063 T6 Al
12	8140	Sill Riser - 1-5/8"	6063 T6 Al
13	8139	Sill Riser - 2-3/4"	6063 T6 Al
14	8138	Sill Riser - 3-1/2"	6063 T6 Al
15	8137	Sill Riser - 4-1/2"	6063 T6 Al
16	8182	Sill Riser - 5-1/4"	6063 T6 Al
17	8119A	Ext. Sill Cover with Screen Rail	6063 T6 Al
18	8117	Int-Ext. Sill Cover	6063 T6 Al
19	8115	Mid-Sill Cover	6063 T6 Al
20	8183	Sill Mounting Strip/Anchor Plate	6063 T6 Al
21	8012	Panel Stile	6063 T6 Al
22	8014C	Top/Bottom Rail	6063 T6 Al
23	8013C	9" Tall Bottom Rail	6063 T6 Al
24	8104	Stile Adaptor	6063 T6 Al
25	8102	Interlock Adaptor (Single)	6063 T6 Al
26	8101	Interlock Adaptor (Double)	6063 T6 Al
27	8103	Top Snap Rail Adaptor	6063 T6 Al
28	8105	Astragal Backup Plate	6063 T6 Al
29	8192	Interlock Reinforcement	6105 T5 Al
30	8200	Interlock Screw Cover with T-slot	6063 T6 Al
31	8136	Frame Screw Cover	6063 T6 Al
32	8107C	Astragal	6063 T6 Al
33	8110	90° Corner Lock Astragal	6063 T6 Al
34	8111	90° Corner Astragal Receiver	6063 T6 Al
35	8204	135° Corner Astragal	6063 T6 Al
36	8205	135° Passive Corner Mount	6063 T6 Al
37	8112	90° Corner Astragal Backup Plate	6063 T6 Al
38	8108	Pocket Door P-Hook	6063 T6 Al
39	8109	Pocket Door P-Hook Mount	6063 T6 Al
40	8141	Screen Frame Add-on (Sill)	6063 T6 Al
41	8142A	Screen Frame Add-on (Head)	6063 T6 Al
42	8143A	Screen Track Addon	6063 T6 Al

TABLE D, CONTINUED:


Bill of Material			
#	Part #	Description	Material
44	6TP248	Vinyl Bulb Weatherstrip @ Interlock	Flex PVC
45	6TP247	Vinyl Bulb Weatherstrip @ P-hook	Flex PVC
46	1644	.187" X .270" Weatherstrip	
47	1673	.500" Door Seal	
50		5/16" X 2" Lagbolt	SS
51	8197	Lagbolt Washer	SS
52	8153	Tandem Roller Assembly	SS
53	8153	Tandem Roller Assembly	Nylon
54		#10" X 1-1/2" Ph. PH. SMS @ Roller	SS
55	8052	Roller Adj. Hole Plug	PVC
60	8022	Interior Bead	6063 T5 Al
61	8150	7/16" OG Bead	6063 T5 Al
62	8145	9/16" OG Bead	6063 T5 Al
63	8146	1-1/16" OG Bead	6063 T5 Al
64	8150	7/16" Square Bead	6063 T5 Al
65	8148	9/16" Square Bead	6063 T5 Al
66	8149	1-1/16" Square Bead	6063 T5 Al
67	6TP247	Vinyl Glazing Bulb	
68	1643	Foam-filled Glazing Bulb (7/16" glazing only)	
69		Dow 899, 995 or Instantglaze Glazing Silicone	Silicone
70	1725	Setting Block, 1/2" X 4" X 1/16", 85 +/- 5 duro.	EPDM
71	1726	Setting Block, 1" X 4" X 1/16" (IG), 85 +/- 5 duro.	EPDM
80	710X34PPSDAX	#10 X 3/4" Ph. PH. SMS @ P-hook	SS
82	710X58PPTX	#8 X 5/8" Ph. PH. SMS @ Interlock	SS
83	710X115PPX	#10 X 1-1/2" Ph. PH. SMS @ Astragal	SS
84	1155	#8 X 1" PH. Quad. SMS @ Main frame	SS
85	72087K	Jamb Bumper	
86	76X38PPAX	#6 X .375" Ph. PH. SMS	SS
87	4385	4 Hole Bumper Stop	
88	78X38PPTX	#8 X 3/8" Ph. PH. SMS	Steel
89	8193	"O" Panel Bracket - 12" long	
90		#10 X 3/4" Ph. PH. SMS @ Fixed "O" Bracket to Stile	SS
91		#8 X 3/4" Ph. FH. SMS @ Fixed "O" Bracket to Frame	SS

TABLE D, CONTINUED:

Bill of Material			
#	Part #	Description	Material
92	Varies	Handle Kit	Cast Zinc
93	8185X	Gemini Mortice Lock w/Long Trim Plate	SS
94	8184X	Gemini Mortice Lock w/Pocket Trim Plate	SS
95		#10-32 X 1" Ph. FH. MS	Steel
96		#10-32 U-Nut	Steel
97		1" Mortice Keeper, 135° Corner & Straight	SS
98	8187X	3/4" Mortice Keeper, 90° Corner	SS
99		#10 X 1-1/2" Ph. PH. SMS @ Keeper	SS
100	1032X1FPFX	10-32 X 1" Ph. FH. MS	SS
110	4317	Screen Top Rail	6063 T6 Al
111	4318	Screen Bottom Rail	6063 T6 Al
112	4319	Screen Side Rail/Lockstile	6063 T6 Al
113	8152	Screen Interlock Adapter	6063 T6 Al
114	4344	Screen Astragal	6063 T6 Al
115	7SRAZ	Roller	Nylon
116	7SRAX	Roller	SS
117		1/4" X 1" MS @ Top Rail	SS
118		1/4" X 1-1/2" MS @ Bottom Rail	SS
119		Screen Lockset	Steel
120	653	Screen Lock Keeper	Steel
121	1179	#10 X 3/4" Ph. PH. SMS @ Keeper	SS
122	1793	.270" X .150" Weatherstrip	
123	1692	Screen Spline - .165"	Vinyl
124		Screen Cloth	Fiberglass

NOTES:

1) ITEMS # 43, 48-49, 56-59, 76-79, 81 & 101-109 ARE NOT USED AND ARE NOT PART OF THIS APPROVAL.



CERT. OF AUTH. #29296

1070 TECHNOLOGY DRIVE
N. VENICE, FL 34275
(941)-480-1600

Series	Rev A Desc.		Title		Date	
	ALUMINUM SLIDING GLASS DOOR NOA (LM)		PARTS LIST		10/05/15	
	J ROSOWSKI		By		J ROSOWSKI	
Rev B	Rev A		Rev A		Rev A	
	Date		Date		Date	
	Date		Date		Date	
SGD-780		Scale	NTS	Sheet	18 OF 18	DWG No.
MD-780.0		Rev No.		A		

PRODUCT REVISED
as complying with the Florida
Building Code
Acceptance No. 16-0629-10
Expiration Date AUG 02, 2017
A. Lynn Miller, P.E.
Attn: Product Control

